# FIRE AND DAMAGE REPORT

SAFETY AND LOSS-PREVENTION DEPARTMENT

*Refer to Safety and Loss Prevention Bulletin No. 24 for the preparation of this report. Use back for additional information.*

| PLANT | DEPARTMENT | LOCATION - BLDG., FLOOR, ROOM | SUPERVISOR |
|---|---|---|---|
| Chicago Plant | Organic Chemicals | Bldg. 20 overhangs | A. Howard |

| DATE AND TIME OF OCCURRENCE | DISCOVERED BY | REPORTED BY | TIME ARRIVED | TIME LEFT |
|---|---|---|---|---|
| 3/4/79 5:00 A.M. | A.D.T. | A. Howard | - | - |

| ALARM BOX NO. | OTHER ALARM USED | INSURANCE CO. REPORTED TO | OFFICE | DATE | FIRE EQUIPMENT RESTORED TO USE |
|---|---|---|---|---|---|
| - | - | - | - | - | ☒ YES ☐ NO |

WHAT FIRE EXTINGUISHMENT EQUIPMENT WAS USED

None

OUTSIDE ASSISTANCE, IF ANY

None

DATE RECEIVED
MAR 12 1979

| | |
|---|---|
| | DEPT. |
| | MGR. |
| | SUP. |
| EVD | |
| DJK | |
| LJS | |
| FILE | REV. |

DESCRIBE ANY FAILURE OF FIRE PROTECTIVE EQUIPMENT

Alarm bell on sprinkler supply line did not sound.

DESCRIPTION OF OCCURRENCE (TELL WHAT HAPPENED)

Due to heavy ice and rain on Bldg. 20 overhangs, about 60 feet of the west side fell, breaking one sprinkler line.

CAUSE OF OCCURRENCE (EXPLAIN HOW AND WHY)

Record snow falls followed by fast melting and 2 inch rainfall caused heavy ice to form on the overhang.

PREVENTIVE ACTION TAKEN

Install new metal overhang on the west side and A.D.T. called in to repair all alarm bells.

INJURIES TO PERSONNEL

None

| REPORTED BY - SIGNATURE | DATE | REVIEW BY - SIGNATURE | DATE |
|---|---|---|---|
| A. Howard | 3/4/79 | R. Johnson | 3/5/79 |

**PRELIMINARY LOSS REPORT** – *Do not hold this report for detailed loss data. Forward within 7 days.*

DESCRIPTION OF DAMAGE TO BUILDING

60 feet Bldg. 20 west overhang lost — ESTIMATED LOSS $5,500.00

DESCRIPTION OF DAMAGE TO EQUIPMENT

None — ESTIMATED LOSS $

DESCRIPTION OF DAMAGE TO PRODUCT

None — ESTIMATED DAMAGE $

| ESTIMATE OF USE & OCCUPANCY LOSS IN DOLLARS | ESTIMATE OF TOTAL PROPERTY LOSS IN DOLLARS |
|---|---|
| None | $5,500.00 |

ESTIMATE OF QUANTITY OF PRODUCTION LOST

None

| ESTIMATE OF DOWNTIME BEFORE RETURN TO 100% OPERATION | ESTIMATE OF TOTAL PROPERTY & U&O LOSS IN DOLLARS |
|---|---|
| None | $5,500.00 |

| ESTIMATES BY - SIGNATURE | DATE | APPROVED BY - SIGNATURE | DATE |
|---|---|---|---|
| R. Johnson | 3/5/79 | | |

N12487