

MARTIN M. GURTLE, JR.
PRESIDENT

LEONARD B. HEBERT, JR.
EXECUTIVE VICE PRESIDENT

P. A. TERRON
VICE PRESIDENT

FRED C. MAU
VICE PRESIDENT

JAN. SIMPSON
VICE PRESIDENT

THOMAS A. DELRA
SECRETARY & TREASURER

GURTLE, HEBERT & CO., INC.

CIVIL ENGINEERS & GENERAL CONTRACTORS

MAIL
P. O. BOX 8066



TELEPHONE
947-0821

1539 PLEASURE STREET
NEW ORLEANS, LA. 70122

Copy to HSC

Sargent & Lundy
140 South Dearborn Street
Chicago, Illinois 60603

Attention: Mr. Rasmussen

Gentlemen:

Subject: Proposal for Pittsburgh
Plate Glass Company, Chemical
Division, Riverside Station
Superstructure, Lake Charles,
Louisiana.

With regard to our telephone conversation of April 12, 1967, Gurtler, Hebert & Co., Inc., submits for your review a tentative list of subcontractors and vendors that we intend to use on the subject job if you elect to use our services as a general contractor.

Corrugated asbestos siding - Corbesco
525 South Johnson
New Orleans, Louisiana

Plumbing - Troth Plumbing Company
Sulphur, Louisiana

Electrical - Sulphur Electric Company
Lake Charles, Louisiana

Fencing - Hercules Fence Company
Lake Charles, Louisiana

Roofing and sheet metal - Pontchartrain Roofing &
Sheet Metal Company
3000 Rabbit Street
New Orleans, Louisiana

BB 0011789

SARGENT & LUNDY
ENGINEERS
CHICAGO

Mr. D. Q. Schultz

May 22, 1967
Page 2

Please advise if the premolded closure is closed cell neoprene and furnish information on the adhesive that is to be applied.

The 1/2" x 3/32" butyl tape is not thick enough. We will approve a 1/2" x 3/16" thick tape. We believe the sample submitted was manufactured by Tremco. We have had excellent results with butyl tape manufactured by Protective Treatments, Inc., 420 Dellrose Avenue, Dayton, Ohio.

The hook and J clip samples appear to be hot dip galvanized. The Z clip sample appears to be electroplated and is not acceptable.

The lead headed bolts are electroplated and shall be dipped in paint prior to erection as specified in Specification K-2342, Article 5, Table 5-3, Item 1.

Please instruct Corrugated Asbestos Contractors to submit erection drawings, typical details and material lists for approval.

Yours very truly,

SARGENT & LUNDY

BY *[Signature]*

ACRaschussen:dp
In Octuplicate
cc: T. M. Ashton (1 w)

| BB 0011790 |