Monsanto	INSTRUMENT FUNCTION OUTLINE	CED LOOP NO. LIA-329-1	
	PLANT W. G. Krummrich	ISSUED BY C. J. Hans DATE 7/29/71	PLANT LOOP NO.
DIVISION Organic	BLDG/DEPT 811.00 / AUTH NO. 2417	REV. BY / DATE	REV / SHEET 1 OF

NO. 2 INTERMEDIATE STORAGE LEVEL

1.0 NEED FOR LOOP

The still pot is both batch charged and "chain" fed with Aroclors in this tank. Accurate level measurement is essential for this very active in-process tank for smooth refining operations.

1.1 DESCRIPTION OF LOOP

1.1.1 Function

The function of this loop is to measure and indicate the level of material and to alarm on high level.

1.1.2 System Performance Required

1.1.3 Accomplishment of Function

A diaphragm type level transmitter senses the liquid level in the tank and sends a proportional 3-15 psig air signal to a 0-100% indicator on the panel and also one near the transmitter. This signal is also sent to a pressure switch which actuates an alarm on high level.

PCB-ARCH-EXT0374056

Per 8*
4*
5*

Monsanto COMPANY LOCATION WGK	*DIFFERENTIAL PRESSURE *INSTRUMENT SPECIFICATIONS	DIVISION 002 / AUTH NO. 2417	PLANT WGK / DEPT OR AREA 246	*SPEC NO. IS-2417-32 / SHEET 3 OF 5 / REV 0

1	Instrument No.			2417 - LIA-329-1									
	Service			LEVEL INDICATOR									
	Equipment No. or Line No. & Size			-329-									
	Process Material			AROCLOR									
3	CASE	Blind, Indicating, Record, Control, Transmit		INDICATING									
		Mounting: Flush, Surface Yoke		NOZZLE									
		CHART	Size and Type										
			Range										
			Drive / Speed										
		SCALE	Size & Type	3-15 PSIG LOCAL PRESS GAGE									
			Range	0-100 LIN									
	DIFFERENTIAL UNIT	Flow, Level, Pressure		LEVEL									
		Bellows, Diaphragm, Other		DIAPHRAGM									
7*		*Span & Units		34" W.C.									
		Range Limits		200" TO 850"									
		Body Rating @ 60°F		180 PSIG									
6*		*Body Material		C.S.									
		Element Material		316 SS									
		Wetted Parts Material		C.S. & 316 SS									
		Extended Diaph. Length		-									
		Fluid Sp. Gr.		1.25									
	SIGNALS	PROCESS INPUT	Liquid, Gas, Cond. Vapor	LIQUID									
			Operating Pressure	ATM									
		INSTRUM. OUTPUT	Range & Units	3-15 PSIG									
			To	0-100 LIN PRESS GAUGE									
		Power Supply – Electrical, Pneumatic		PNEW									
		Electrical Area Classification		WEATHER TITE									
	CONTROLLER	Proportional Band %											
		Auto-Reset Mode		NO / SLOW / FAST	NO	SLOW	FAST	NO	SLOW	FAST	NO	SLOW	FAST
		Rate Mode		YES / NO	YES	NO		YES	NO		YES	NO	
		Auto-Manual By Pass		YES / NO	YES	NO		YES	NO		YES	NO	
		On Measurement Increase Instrument Output		INC. / DEC	INC.	DEC		INC.	DEC		INC.	DEC	
		Pipe & Mt'd Air Supply Reg.		(YES) / NO	YES	NO		YES	NO		YES	NO	
		Output Gage, 3½" Size		(YES) / NO	YES	NO		YES	NO		YES	NO	
	REMARKS	Accessories or Special Features											
		FLANGE, 3" - 150# R.F.		YES									
		AIR SUPPLY SET, 2" GAGE		B-110-2M P-102-SIN									
		OUTPUT GAGE 0-100 LIN		YES									
				SET ZERO									
				WITH 4" W.C. ON									
				HIGH SIDE									
2	PURCH.	Manufacturer		FOXBORO									
		Catalog No.		13FA1-HK 315									
		P.O. No.		0038									
		Price		$400									

REV.	DATE												
0		PREPARED	EIH	12/23/70	4								
1		REVISED	CJH	7/30/71	5								
2					6								
3					7								

ES 117 (10/66)

PCB-ARCH-EXT0374057

Monsanto	INSTRUMENT FUNCTION OUTLINE		CED LOOP NO. LIA-329-1		
	PLANT W. G. Krummrich		ISSUED BY C. J. Hans DATE 7/29/71		PLANT LOOP NO.
DIVISION Organic	BLDG/DEPT 811.00	AUTH NO. 2417	REV. BY	DATE	REV / SHEET OF

3.0 OPERATION

3.1 NORMAL OPERATION

Typical level loop.

3.2 INTERLOCKS

None.

3.3 ABNORMAL OPERATIONS

3.3.1 Air Failure

Air failure to the loop will cause loss of indication.

3.3.2 Power Failure

Loss of power will cause alarm to be inoperative.

NOTE: The zero of level transmitter should be set after N_2 blanketing system is in operation. N_2 enters and is regulated @ 4" W.C. and relieves at 7" W.C. Since the low side is not compensated, it will be necessary to run the zero elevated @ almost 5" W.C.

ES 141
8/69)

PCB-ARCH-EXT0374058