

Facility Name/Address (Include Facility Name/Location if different)

NAME PPG IND.
ADDRESS P. O. BOX 1000
LAKE CHARLES LA 70602

FACILITY
LOCATION

ATTN: T. G. Brown, Plant Manager

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

LA0000761
PERMIT NUMBER

001
DISCHARGE NUMBER

F - FINAL LIMITS
FINAL OUTFALL

Form Approved
OMB No. 2040-0004
Expires 2-29-84

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
86	01	01	86	01	31
(10-21)	(12-21)	(24-24)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	85	85	NA	CONT	RECORD
EFFLUENT GROSS VALUE FLOW RATE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	DEG. F	CONTIN	RECORD
00058 1 0	SAMPLE MEASUREMENT	146,653	211,091	GPM	*****	*****	*****	NA	CONT	RECORD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	30DA AVG	DAILY MX	*****	*****	*****	*****	*****	CONTIN	RECORD
PH	SAMPLE MEASUREMENT	*****	*****	*****	5.7	*****	9.0	0	CONT	RECORD
00400 1 0	PERMIT REQUIREMENT	*****	*****	*****	6.0	*****	9.0	0	CONTIN	RECORD
EFFLUENT GROSS VALUE		446		MIN/MO	MINIMUM		MAXIMUM		UOUS	
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4500

AREA CODE

NUMBER

DATE

86 01 31

YEAR MO DAY

SAMPLE AND EXPLANATION OF VARIATIONS (Reference all attachments here)

THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

*Duration of excursion did not exceed 60 minutes, and therefore did not constitute a violation.

SL 7293

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PPG IND.
ADDRESS P. O. BOX 1000
LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)
LA0000761
PERMIT NUMBER

(17-19)
005
DISCHARGE NUMBER

F - FINAL LIMITS
SURFACE RUNOFF

Form Approved
OMB No. 2040-0004
Expires 2-29-84

FACILITY
LOCATION

ATTN: T. G. Brown, Plant Manager

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
86	01	01	86	01	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0 EFFLUENT GROSS VALUE FLOW RATE	SAMPLE MEASUREMENT	*** **	*** **	*** **	*** **	79	82		NA	3/7	GRAB
	PERMIT REQUIREMENT	*** **	*** **	*** **	*** **	*** **	*** **	DEG. F		THREE	GRAB WEEK
00058 1 0 EFFLUENT GROSS VALUE PH	SAMPLE MEASUREMENT	448	680		*** **	*** **	*** **	*** **	NA	3/7	GRAB
	PERMIT REQUIREMENT	*** **	*** **	GPM	*** **	*** **	*** **	*** **		THREE	GRAB WEEK
		30DA AVG	DAILY MX								
	SAMPLE MEASUREMENT	*** **	*** **	*** **	7.3	*** **	11.9*	L = 0 H = 2		3/7	GRAB
00400 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*** **	*** **	*** **	6.0 MINIMUM	*** **	9.0 MAXIMUM	SU		THREE	GRAB WEEK
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1318. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318
AREA
CODE

491-4500
NUMBER

86

01

31

YEAR

MO

DAY

HEREIN SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

047294

For see letter of 1/22/86 as noted in Attachment I

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PPG IND.

ADDRESS P. O. BOX 1000

LAKE CHARLES

LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

PERMIT NUMBER

010

DISCHARGE NUMBER

Form Approved

OMB No. 2040-0004

Expires 2-29-84

F - FINAL LIMITS

AREA B UNCONTAMINATED CTBD

FACILITY

LOCATION

TTN: T. G. Brown, Plant Manager

MONITORING PERIOD

YEAR	MO	DAY	TO	YEAR	MO	DAY
86	01	01		86	01	31
(12-11)	(12-11)	(12-11)		(12-11)	(12-11)	(12-11)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-43)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	194	345	GPM	*****	*****	*****	*****	NA	CONT RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** 30DA AVG	***** DAILY MX		*****	*****	*****	*****		CONTINUOUS
CHROMIUM, TOTAL (AS CR)	SAMPLE MEASUREMENT	.023	.161	LBS/DY	*****	*****	*****	*****	0	3/7 24 HC
01034 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	8 DAILY AV	16 DAILY MX		*****	*****	*****	*****		THREE/COMP2 WEEK
CHLORINATED HYDRO- CARBONS, GENERAL	SAMPLE MEASUREMENT	*	*	LBS/DY	*****	*****	*****	*****		
14052 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	684 DAILY AV	1368 DAILY MX		*****	*****	*****	*****		THREE/COMP2 WEEK
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED R PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500 86 01 31
AREA CODE NUMBER YEAR MO DAY

CHLORINATED HYDROCARBONS LIMIT IS SUM OF 010 & 018.

*See Outfall 018.

SL 7295

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PPG IND.

ADDRESS P. O. BOX 1000

LAKE CHARLES

LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

PERMIT NUMBER

011

DISCHARGE NUMBER

F - FINAL LIMITS
MERCURY CELLS SEWER

Form Approved
OMB No. 2040-0004
Expires 2-29-84

FACILITY

LOCATION

ATTN: T. G. Brown, Plant Manager

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
86	01	01	86	01	31
(20-31)	(12-31)	(13-31)	(20-31)	(12-31)	(13-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	202	283	GPM	*****	*****	*****	*****	NA	CONT	RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****			
MERCURY, TOTAL (AS HG)	SAMPLE MEASUREMENT	1.050	.256	LBS/DY	*****	*****	*****	*****	0	3/7	24 HC
71900 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	.21	.42		*****	*****	*****	*****			
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1310. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4500

AREA
CODE

NUMBER

DATE

86 01 31

YEAR MO DAY

HEREIN AND EXPLANATION OF ANY VIOLATIONS (SEE PPG DWG 20A-1-1577-P-6, STREAMS 5,6).

HERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

G IS SUM OF 111 AND 111.

5047296

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **PPG IND.**

ADDRESS **P. O. BOX 1000**

LAKE CHARLES

LA 70602

FACILITY

LOCATION

ATTN: **T. G. Brown, Plant Manager**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

PERMIT NUMBER

111

DISCHARGE NUMBER

**F - FINAL LIMITS
MERCURY TRACE SEWER**

Form Approved
OMB No. 2040-0004
Expires 2-29-84

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	86	01	01		86	01	31
	(20-21)	(22-24)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	396	459	GPM	*****	*****	*****	*****	NA	CONT	RECORD
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** 30DA AVG	***** DAILY MX		*****	*****	*****	*****		CONTINUOUS	RECORD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

**T. G. Brown
Works Manager**

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318

491-4500

86

01

31

AREA
CODE

NUMBER

YEAR

MO

DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

047297

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PPG IND.

ADDRESS P. O. BOX 1000

LAKE CHARLES

LA 70602

FACILITY

LOCATION

ATTN: T. G. Brown, Plant Manager

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

PERMIT NUMBER

012

DISCHARGE NUMBER

F - FINAL LIMITS
HG CELL COOLING TWR BLOWDOWN

Form Approved
OMB No. 2040-0004
Expires 2-29-84

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
86	01	01	86	01	31
(20-31)	(12-31)	(24-24)	(26-31)	(12-31)	(10-31)

FROM

TO

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	NO DISCHARGE			*****	*****	*****	*****	NA	7/7	24 HT
00058 1 0	PERMIT REQUIREMENT	*****	*****	GPM	*****	*****	*****	*****		THREE/CALCT	
EFFLUENT GROSS VALUE		30DA AVG	DAILY MX							WEEK	
MERCURY, TOTAL (AS HG)	SAMPLE MEASUREMENT	NO DISCHARGE			*****	*****	*****	*****	NA	3/7	24 HC
71900 1 0	PERMIT REQUIREMENT	*****	*****	LBS/DY	*****	*****	*****	*****		THREE/COMPZ	
EFFLUENT GROSS VALUE										WEEK	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318

491-4500

86

01

31

AREA
CODE

NUMBER

YEAR

MO

DAY

COMMENT: NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

MERCURY SAMPLE TYPE LINEAR OR TIME COMPOSITE

SL 87298

00 01 31

NOTE: Read instructions before completing this form.

		QUANTITY OR LOADING			(4 Card Only) (38-43)	QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS		(46-53) MINIMUM	(54-61) AVERAGE	(54-61) MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	128,589	178,211	GPM	*****	*****	*****	*****	NA	CONT	CALC.
00058 1 0	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		CONTINUOUS	CALC.
EFFLUENT GROSS VALU		30DA AVG	DAILY MX								
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
318	491-4500	86	01	31
AREA CODE	NUMBER	YEAR	MO	DAY

STATE AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SL 047299

PERMITTEE NAME/ADDRESS (Include
Facility Name/Location if different)

NAME PPG IND.

ADDRESS P. O. BOX 1000

LAKE CHARLES

LA 70602

FACILITY

LOCATION

ATTN: T. G. Brown, Plant Manager

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

PERMIT NUMBER

017

DISCHARGE NUMBER

F - FINAL LIMITS

LEAD TREATMENT DISCHARGE

Form Approved

OMB No. 2040-0004

Expires 2-29-84

MONITORING PERIOD

YEAR	MO	DAY	TO	YEAR	MO	DAY
86	01	01		86	01	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	17	48	GPM	*****	*****	*****	*****	NA	CONT
00058 1 0	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		CONTIN
EFFLUENT GROSS VALUE		30DA AVG	DAILY MX							CORD
SOLIDS, TOTAL	SAMPLE MEASUREMENT	.21	.21	LBS/DY	*****	*****	*****	*****	NA	3/7
SUSPENDED	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		24 nc
00530 1 0										THREE/COMP2
EFFLUENT GROSS VALUE										WEEK
LEAD, TOTAL	SAMPLE MEASUREMENT	.001	.001	LBS/DY	*****	*****	*****	*****	0	3/7
(AS PB)	PERMIT REQUIREMENT	5.1	10.1		*****	*****	*****	*****		24 HC
01051 1 0		DAILY AV	DAILY MX							THREE/COMP2
EFFLUENT GROSS VALUE										WEEK
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318
AREA
CODE

491-4500
NUMBER

86
YEAR

01
MO

31
DAY

SEE PPG-DWG 20A-1577-UP-STREAM 18.

THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SL 047300

DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004
Expires 2-29-84F - FINAL LIMITS
PROCESS WASTEWATERNAME LAKE CHARLESADDRESS P.O. BOX 1000LAKE CHARLESLA 70602

LA0000761

PERMIT NUMBER

018

DISCHARGE NUMBER

FACILITY

LOCATION

LINE: T. G. Brown, Plant Manager

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
86	01	01	86	01	31
(12-31)	(12-31)	(12-31)	(12-31)	(12-31)	(12-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	6,079	6,830	GPM	*****	*****	*****	*****	NA	RECORD
10058 1 0	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****	CONTINUOUS	RECORD
EFFLUENT GROSS VALUE		300A AVG	DAILY MX							
5-DAY	SAMPLE MEASUREMENT	391	961	LBS/DY	*****	*****	*****	*****	0	24 HC
(20 DEG. C)	PERMIT REQUIREMENT	774	1298		*****	*****	*****	*****	1/7	WEEKLY
0310 1 0		DAILY AV	DAILY MX							COMP24
EFFLUENT GROSS VALUE										
SOLIDS, TOTAL	SAMPLE MEASUREMENT	2,084	*****	LBS/DY	*****	*****	*****	*****	0	24 HC
UNSPENDED	PERMIT REQUIREMENT	3100	*****		*****	*****	*****	*****	3/7	WEEK
0530 R 0		300A AV								COMP24
SEE COMMENTS BELOW										
SOLIDS, TOTAL	SAMPLE MEASUREMENT	1,908	6,131	LBS/DY	*****	*****	*****	*****	0	24 HC
UNSPENDED	PERMIT REQUIREMENT	4500	8700		*****	*****	*****	*****	3/7	WEEK
0530 1 0		DAILY AV	DAILY MX							COMP24
EFFLUENT GROSS VALUE										
TOTAL ORGANIC CARBON	SAMPLE MEASUREMENT	754	1,221	LBS/DY	*****	*****	*****	*****	0	24 HC
(TOC)	PERMIT REQUIREMENT	1300	2600		*****	*****	*****	*****	3/7	WEEK
0680 1 0		DAILY AV	DAILY MX							COMP24
EFFLUENT GROSS VALUE										
CHLORINATED HYDRO-	SAMPLE MEASUREMENT	36	55	LBS/DY	*****	*****	*****	*****	0	24 HC
CARBONS, GENERAL	PERMIT REQUIREMENT	684	1368		*****	*****	*****	*****	3/7	WEEK
052 1 0		DAILY AV	DAILY MX							COMP24
EFFLUENT GROSS VALUE										
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318
AREA
CODE491-4500
NUMBER

86

01

31
DAY

CHLORINATED HYDROCARBONS LIMIT IS THE SUM OF 018 AND 010. TSS IS ANNUAL AVERAGE.

SL 047301

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PPG IND.

ADDRESS P. O. BOX 1000

LAKE CHARLES

LA 70602

FACILITY

LOCATION

ATTN: T. G. Brown, Plant Manager

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

PERMIT NUMBER

019

DISCHARGE NUMBER

F - FINAL LIMITS

SUM OF 011,017,019, FLOW & TSS

Form Approved

OMB No. 2040-0004

Expires 2-29-84

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 86	01	01	TO 86	01	31
(12-1)	(12-1)	(12-1)	(12-1)	(12-1)	(12-1)

NOTE: Read Instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	341	439	GPM	*****	*****	*****	*****	NA	CONT
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****		*****	*****	*****	*****		RECORD
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	22	56	LBS/DY	*****	*****	*****	*****	0	3/7
00530 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	1118	2236		*****	*****	*****	*****		24
	SAMPLE MEASUREMENT									THREE/COMP2
	PERMIT REQUIREMENT									WEEK
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

318 491-4500

AREA
CODE

NUMBER

DATE

86 01 31

YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VARIATIONS (Reference all attachments here)

TSS IS THE SUM OF 011, 017 AND 019.

SL 047302

NAME PPG IND.
ADDRESS P. O. BOX 1000
LAKE CHARLES LA 70602

DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

LA0000761
PERMIT NUMBER

021
DISCHARGE NUMBER

F - FINAL LIMITS
COOLING WATER

Form Approved
OMB No. 2040-0004
Expires 2-29-84

FACILITY
LOCATION

ATTN: T. G. Brown, Plant Manager

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
86	01	01	86	01	31
(12-11)	(12-11)	(12-15)	(12-17)	(12-19)	(10-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (18-43)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	70	81	NA	CONT	RECORD
EFFLUENT GROSS VALUE FLOW RATE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	DEG. F	CONTINUOUS	RECORD
00058 1 0	SAMPLE MEASUREMENT	13,762	18,400	GPM	*****	*****	*****	NA	CONT	RECORD
EFFLUENT GROSS VALUE PH	PERMIT REQUIREMENT	300A AVG	DAILY MX		*****	*****	*****	CONTINUOUS	RECORD	RECORD
00400 1 0	SAMPLE MEASUREMENT	*****	*****	*****	6.2	*****	9.5	NA	CONT	RECORD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	MINIMUM	*****	MAXIMUM	SU	CONTINUOUS	RECORD
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500

86 01 31

AREA
CODE

NUMBER

YEAR

MO

DAY

TYPED OR PRINTED

HERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.

SL 047303

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PPG IND.

ADDRESS P. O. BOX 1000

LAKE CHARLES

LA 70602

FACILITY

LOCATION

ATTN: T. G. Brown, Plant Manager

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

LA0000761

PERMIT NUMBER

024

DISCHARGE NUMBER

F - FINAL LIMITS

SURFACE DRAINAGE - PRODN STRG

Form Approved

OMB No. 2040-0004

Expires 2-29-84

MONITORING PERIOD

YEAR	MO	DAY	TO	YEAR	MO	DAY
86	01	01	TO	86	01	31
(20-21)	(12-13)	(14-15)		(26-27)	(18-29)	(10-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
PH	SAMPLE MEASUREMENT	*****	*****	*****	8.3	*****	8.9	L = 0	5/7*	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	6.0	*****	11.0	H = 0		
00400 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT				MINIMUM		MAXIMUM	SU	WEEK-DAYS	GRAB
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC. § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 491-4500 86 01 31

AREA CODE NUMBER YEAR MO DAY

INDICATE INSTANCES OF NONCOMPLIANCE (Reference all attachments here)

*When wing. | - |

L 047304

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PPG IND.
ADDRESS P. O. BOX 1000
LAKE CHARLES LA 70602

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)
LA0000761
PERMIT NUMBER

(17-19)
025
DISCHARGE NUMBER

F - FINAL LIMITS
STORM DRAINAGE 1500 T/D CHLRN

Form Approved
OMB No. 2040-0004
Expires 2-29-84

FACILITY
LOCATION
ATTN: T. G. Brown, Plant Manager

MONITORING PERIOD
FROM YEAR MO DAY TO YEAR MO DAY
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)
86 01 01 TO 86 01 31

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53) (54-61)			UNITS	(4 Card Only) QUALITY OR CONCENTRATION (58-65) (64-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM			MINIMUM	AVERAGE	MAXIMUM			
FLOW RATE	SAMPLE MEASUREMENT	2,467	26,921	GPM	*****	*****	*****	*****	NA	5/7*	GRAB
00058 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	***** 30DA AVG	***** DAILY MX		*****	*****	*****	*****	*****		DAILY
PH	SAMPLE MEASUREMENT	*****	*****	*****	9.0	*****	10.8		NA	5/7*	GRAB
00400 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	***** MINIMUM	*****	***** MAXIMUM	SU		DAILY	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 | 491-4500

86 | 01 | 31

AREA CODE

NUMBER

YEAR

MO

DAY

TYPED OR PRINTED

MEMBER EXPLANATION OF ABBREVIATIONS (Reference all attachments here)

HERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM EXCEPT IN TRACE AMOUNTS.
UNITUR WHILE FLOWING ALL PARAMETERS. *When flowing.

047305

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME PPG IND.

ADDRESS P. O. BOX 1000

LAKE CHARLES

LA 70602

FACILITY

LOCATION

ATTN: T. G. Brown, Plant Manager

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

(1-19)

F - FINAL LIMITS
STORM DRAINAGE

Form Approved
OMB No. 2040-0004
Expires 2-29-84

LA000761

026

PERMIT NUMBER

DISCHARGE NUMBER

MONITORING PERIOD

YEAR	MO	DAY	TO	YEAR	MO	DAY
86	01	01	86	01	31	
(28-31)	(22-31)	(24-25)	(28-31)	(28-29)	(28-31)	

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-43)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	30	180		*****	*****	*****	*****	NA	5/7*	GRAB
00058 1 0 EFFLUENT GROSS VALUE PH	PERMIT REQUIREMENT	***** 30DA AVG	***** DAILY MX	GPM	*****	*****	*****	*****		WEEK- DAYS	GRAB
00400 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	5.7	9.9			NA	5/7*	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	***** MINIMUM	***** MAXIMUM	*****	SU		WEEK- DAYS	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

T. G. Brown
Works Manager

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

318 | 491-4500 | 86 | 01 | 31

AREA
CODE

NUMBER

YEAR

MO

DAY

MONITOR FLOW WHEN FLOWING (Reference all attachments here)

*When Flowing.

047306

Attachment I

There were two excursions in January reported by letter as follows:

January 14, 1986 (+2.5) pH @ Outfall 005. A small leak developed in a weld due to corrosion on a 50% caustic transfer line outside an operating area allowing material to enter a drain to Outfall 005. Because of the low flow through Outfall 005, the small amount of caustic caused the permit limit to be exceeded. The leak was found after intensive investigation (after the second violation on 1/16/86) because the transfer line is used only intermittently. As soon as discovered, the transfer pumps were shut down and the leak repaired. Subsequent pH samples on this outfall have been within the NPDES permit limits.

January 16, 1986 (+2.9) pH @ Outfall 005. See above.