

INTERNAL  
CORRESPONDENCEUNION CARBIDE CORPORATION TECHNICAL CENTER  
P.O. BOX 8361, SOUTH CHARLESTON, WV 25303To (Name) A. F. Terry  
Division 704  
Location 511  
Area

Date June 25, 1987

Originating Dept. EM&amp;TS - HS&amp;EA

Area Industrial Hygiene

Copy to D. L. Brown - 704  
C. P. Maxwell - 701/2  
C. L. Ruddle - 704  
R. E. Sergeant - 704Subject Asbestos Bulk Sample  
Analysis**PLAINTIFF'S  
EXHIBIT**  
UC-768

Two samples you submitted for asbestos analysis showed the following results:

1. Material labeled Pipe Insulation - contained asbestos.
2. Material labeled Paper Pipe Insulation - did not contain asbestos.

These samples were collected from the Utility lines in the Laboratory located on the third floor of Building 701 undergoing renovation. The results were verbally communicated to you by V. E. Stover of our group.

*Manhar A. Patel*  
\_\_\_\_\_  
Manhar A. Patel

MAP:rab  
2425P