

Table 2 Relation of Resistor Voltage to Heat Delivery

Condition	Volts	Heat Delivered %
Electric system, nominal value	120/240	103.3
For design of equipment, at terminals	118/236	100
Range, as basis for design		
Minimum	110/220	86.8
Maximum	124/248	110.5
On secondary distribution system		
Favorable zone, as to voltage conditions		
Minimum	110/220	86.8
Maximum	125/250	112.0
Tolerable zone		
Minimum	107/214	82.2
Maximum	127/254	116.8
Emergency conditions	90/180	58.3

design of heating system, and internal sources of heat. Experience with many thousands of electric heating installations has shown that a conservative value for C is 18.5. Values of C as low as 12 have been reported on individual installations. It is recommended that a value of C of 18.5 be used unless local experience of a statistical nature has established a more reliable value for the particular area concerned in the estimate.

For block-type electric rates, multiplying the annual kilowatt-hour energy consumption by the cost per kilowatt-hour indicates the annual cost. For demand rates, the assistance of the local utility company should be secured to estimate demand and energy uses by the month on the particular rate involved. It may be pointed out that residences with thermostat control in each room generally establish a maximum of 75 percent of the total calculated heat load as the highest demand requirement for heating.

Voltage Requirements

The preferred nominal system voltage at point of electric utilization by equipment, for single-phase 3-wire systems necessary with space heating, is 120/240 volts, as stipulated by standards of the electrical industry (*EEI Publication R-6* and *NEMA Publication No. 117* issued May 1949). For household heating appliances mentioned in the standards, such as air heaters, water heaters, and cooking ranges, the equipment voltage rating for design is specified as 118/236 volts, and the range of voltages to be used as a basis of design extends from 110/220 minimum to 124/248 maximum. However, natural variations exist from time to time in the conditions at different points in any secondary distribution system and will affect both voltage level and range of fluctuations. Under emergency conditions on electricity supply systems, voltages of the order of 90/180 may be encountered. Heat delivery by resistors with these voltage values, expressed in percent of rated delivery with the normal 118/236 volts (at terminals) is given in Table 2.

Voltages stipulated for secondary distribution systems are at point of service entrance to the building; the drop of voltage in the house supply wiring to terminals of the heating equipment may be 2 to 3 percent, thus reducing heat delivery by some 5 to 8 percentage points below the favorable zone and tolerable zone values included in the last column of Table 2. Accordingly, it is necessary the designers of electric heating installations obtain specific information from the local electric utility company on both existing and anticipated

future conditions at the location, before specifying the capacity and voltage for equipment, wiring, and controls.

BIBLIOGRAPHY

- W. F. Friend: Electric house heating—load characteristics and economics (*Midwest Power Conference Proceedings*, April 1951).
- E. E. Parks: Electric house heating (*Electrical Engineering*, August 1951).
- Electric House Heating* (*Rural Electrification Administration Bulletin* 142-1, December 1957).
- F. A. Compton: *Complete Electric House Heating* (*Edison Electric Institute Bulletin*, May 1950).
- C. E. Simpson: House heating experience (*Electrical World*, October 9, 1948).
- B. H. Martin and T. W. Newberry: Heating by electricity in Tennessee valley area (*Heating and Ventilating*, May 1948).
- H. G. Kelsey: Longview house heating data (*Electrical West*, September 1945).
- W. B. Morrison: Electric storage heating serves new Oregon school (*Heating, Piping and Air Conditioning*, June 1949).
- R. E. Sinclair: Electric house heating load characteristics (*Electrical West*, September 1950).
- J. B. Cochran: House heating load characteristics as they affect wiring costs (*Electrical World*, April 12, 1947).
- H. C. Bender: Heat factor formula to calculate electric house heating (*Electrical World*, May 12, 1945).
- W. F. Friend: Modulating and load-limiting controls for electric house heating (*American Power Conference Proceedings*, March 1953, and *Heating and Ventilating*, August 1953, p. 82).
- Methods developed for built-in radiant heat (*Electrical West*, December 1948).
- R. J. Lorenzi and J. F. Schreiber: Performance of electrical system of panel heating with four stages of insulation (*Heating, Piping and Air Conditioning*, January 1949).
- L. N. Roberson: Radiant heating by electricity (*Heating and Ventilating*, September 1948, p. 89).
- R. S. Tice: Low-voltage high-current radiant heat (*Electrical West*, December 1947).
- Applications of radiant energy (*Illuminating Engineering Society, Lighting Handbook*, 1952, Section 18).
- Radiant Glass Heating Panels* (National Bureau of Standards, Technical News Bulletin, May 1953).
- P. R. Achenbach: Radiant glass heating panels (*Heating and Ventilating*, January 1953, p. 83).
- EEI-NEMA Preferred Voltage Ratings for A-C Systems and Equipment* (*Edison Electric Institute Publication No. R-6*, May 1949, and *National Electrical Manufacturers Association Publication No. 11*, May 1949).
- Standard Handbook for Electrical Engineers* (McGraw-Hill Book Co., New York, 1952).
- R. E. Sinclair: Short method for estimating electric house heating load (*Air Conditioning, Heating and Ventilating*, January 1955).
- R. L. Boyd: Heat schools electrically? (*Heating, Piping and Air Conditioning*, December 1956).
- NEMA Manual for Electric House Heating* (National Electrical Manufacturers Association, June 1957).
- J. C. Beckett: Cost comparison: resistance space heating vs fuel-fired systems (*Electrical Construction and Maintenance*, October 1956).
- Space heating: what happens in the 6,000 degree-day zone (*Electrical World*, March 19, 1956).
- W. R. New: Serving the all-electric home (*Electrical World*, March 19, 1956).
- R. L. Boyd: It's here . . . the all electric school (*Electrical Construction and Maintenance*, February 1957).
- Handbook of Electrical Applications* (Edison Electric Institute).
- W. J. Novak: Electricity and combustible fuels (*Electrical Construction and Maintenance*, April 1957).

CHAPTER 18

WARM AIR HEATING SYSTEMS

Forced Warm Air Systems; Air Distribution; Supply Outlets and Return Grilles; Duct Construction; Simplified Methods of Design for Perimeter Systems of Loop, Radial, and Extended-Plenum Types; Return Duct System for Perimeter Installations; Inside Wall Delivery Systems; Design of Large Systems; Automatic Controls; Adjustment of System; Warm Air Ceiling Panel Systems; Summer Operation; Gravity Warm Air Systems

WARM air heating systems may be conveniently divided into two classifications depending upon the manner in which the motive power for circulating the warm air is supplied. In gravity systems, the motive head is due to the difference in weight between the heated air leaving the top of the furnace casing and the cooler return air entering the bottom of the casing. In a forced warm air heating system, all or part of the motive head is supplied by a fan. Although a great many gravity warm air heating systems are in use, only a limited number of new gravity installations are now being made. Emphasis will therefore be placed upon the design and installation of forced warm air heating systems.

FORCED WARM AIR SYSTEMS

In forced warm air heating systems, the air circulation is effected by motor-driven centrifugal fans, commonly referred to as blowers. The advantages of forced air systems are:

1. The furnace may be placed in any part of the structure.
2. Distribution ducts can be made small enough to be inconspicuous and out of the way, or be completely concealed from view where desired.
3. Circulation of air is positive, and in a properly designed system, can be controlled in such a way as to give a comfortably uniform temperature distribution.
4. Humidity control is readily attained.
5. The air may be cleaned by filters or other means.
6. If properly designed or suitably adapted, the same air distribution system can be used for summer cooling as for winter heating.
7. The use of the fan permits flexibility in the location of supply and return grilles as required to obtain proper distribution of air for comfort.
8. Ventilation air may be positively introduced and conditioned.

The construction features of forced warm air furnace units and the function and selection of the various parts of a system are discussed in Chapter 35 and other publications.

AIR DISTRIBUTION

The conditions of comfort obtained in a room are influenced greatly by the type of supply outlet used, and the locations of the supply outlets and return grilles. In general it has been found that changes in the type, air velocity, and location of the supply outlet affect the room conditions much more than the changes in the location of the return grilles. Three methods of locating outlets and grilles are in common use. One method is to locate the supply register near the floor so that the warm air from the register blankets a cold wall, and mixes with the cold air descending from the ex-

posed walls and glass. A second method is to locate the supply openings near the floor, or high in the side wall, on the inside wall, and the return openings near the greatest outside exposure. A third method is to locate all supply openings around the outside wall, near the source of the greatest heat loss, usually beneath the windows, and to use grilles designed to blanket the cold area. This causes mixing of the warm air delivered with the cool air from the heat loss area and the cold air from infiltration, thus effectively preventing drafts. It has been called perimeter heating.

In any case, the warm air registers should be so located and so designed that the air stream never discharges directly against people at rest. Tests* in Warm Air Research Residences No. 1 and No. 2 at the University of Illinois, have indicated that nearly continuous blower operation gave better results than intermittent operation. This type of operation is more commonly achieved by suitable adjustments of air quantity and fan switch settings than by continuous operation of the blower.

Supply Outlets and Return Grilles

The type of supply outlet that should be used depends upon the type of distribution system to which it is applied. With perimeter duct systems, the supply outlets are usually located in the floor, in the baseboard, or low in the side-wall and underneath a window. In order to be most effective, perimeter diffusers must deliver the air upward and in a fan-shaped pattern so as to blanket the window or cold wall with warm air, thus mixing with and tempering the cold air which usually descends along a cold surface. Furthermore, since delivery of the air outward into the room, rather than upward, is likely to impinge upon the occupants it should be avoided. With certain types of perimeter diffusers, the air velocity at the diffuser face is limited only by the pressure available at the diffuser and the noise characteristics of the outlet.

Tests with inside wall supply systems conducted in Warm Air Heating Research Residence No. 1 have indicated that comparable results are obtainable with either high side-wall or baseboard registers, if proper registers and air velocities are selected.

Baseboard registers should be of a deflecting-diffuser type that will direct the air downward toward the floor and diffuse it at the same time. For baseboard registers, air velocities over 500 fpm should be avoided as they may cause discomfort.

High side-wall registers should be of a type that will deliver the air horizontally or in a slightly downward direction, and should be so located as to avoid impingement of air on ceiling or wall. Directional flow diffusing type regis-