

Monsanto

FROM (NAME & LOCATION)

Mark Riddle - Texas City, LP&S, 0-22 (Ext. 3236)

DATE May 15, 1984 cc: R. T. Hammann

SUBJECT 1st Quarter Safety & Housekeeping
Inspection - Locker Building and
REFERENCE Safety Supply

TO : Steve Moncla

The following concerns were generated during the 1st Quarter Safety and Housekeeping Inspection of the Locker Building and Safety Supply:

1. Trash cans were blocking two of the rear exits.

Comments: Door catches and door stops will be installed to eliminate the use of the trash cans.

2. Walls in the shower rooms were cracked and paint was peeling off.

Comments: The walls are disinfected on a daily basis. We will re-evaluate the need for further painting.

3. Are boxes stacked four high safe?

Comments: Yes, since the weight, size and height are within acceptable limits.

4. Some showers were dripping.

Comments: Shower heads have since been repacked. This is a continuing problem, but will continue to monitor and repair when necessary.

5. The safety supply area was neat and clean.

Comments: Yea!

6. There appears to be some confusion over "green card" inventory.

Comments: These are STOP cards that were used in the training of supervisors. We don't plan to issue these except in emergency. We have since restocked our supply of STOP cards for plant use.

MARK

Mark Riddle

/dgb

SC

000582

LAM001780