

Interoffice Communication

To : Jim Barton
 From : Ray McGhee
 Date : April 25, 1978
 Subject : VCM RELEASE

On Saturday morning, 4/15/78, at approximately 06:45 Lead Operator, Charles Holcomb, vented 744 reactor through the recovery system. During this venting the recovery bullseye blew out of the recovery line. There was no one in the area at the time of the blow out. Harold Sanders and Reggie Jones were on the way to the control room when the bullseye blew out.

Harold Sanders went back to the unit and closed the manual valve on the knock out tank to stop the leak. Harold was not wearing a Scott Air Pack at the time. The Honeywell unit did not show any high VCM readings in the area at the time and Harold did not smell any VCM. Whether or not he was exposed is not known.

Ray McGhee J. Barton
 Ray McGhee

cjt

c: ELK, AHS