

cc: I. M. Singer #16
G. T. Williams #80
L. T. Wilson #80
J. C. Walker #6
T. W. Clark #43
R. D. Monk #50
G. M. Shaw #50

October 31, 1985

TO: L. T. FREELAND #42
K. C. WEIS #20

FROM: T. A. HOOKS #50 *TAH*

S&OH FIELD OBSERVATION - ASBESTOS GASKET STORAGE

The S&OH team recommended we reevaluate asbestos gasket (G1 & S1) storage to be in compliance with the company recommendations which include storing gaskets in marked plastic bags, covered gasket boards or cabinets. I am requesting the recommendations of the company be reevaluated with consideration being given to:

- The high relative humidity of this area.
- The high probability of the gaskets drying out in covered storage and asbestos dust collecting in the enclosures creating a hazardous condition. See Engineering Standard S4T 2.2 e and 2.4.
- Plant air sampling history of cutting and handling asbestos gaskets. (Available from Engineering Tech. Services)
- The possibility of obtaining goals through education and self management principles. This could include spraying gaskets with fine mist of water when dusting was evident.

P&O will begin an education program including water misting while awaiting your decision.

TAH/cab

DUP 0502890

DU 002327