

UNDERWRITERS LABORATORIES INC.

FACTORY INSPECTION PROCEDURE

Subj. 758
Vol.

Section 5 Page 5049
This Page Effective

Issued: Jan. 31, 1962
Revised: July 1, 1980

Style 5049 Asbestos Insulated, Glass Braided Wire For Use
With Lampholders.

Rating 150 C, 300 volts.

Conductor No. 18-16 AWG, stranded, same as for Type AF wire.

Insulation Acetate tape used as separator over which
is applied a nominal 1/64 inch wall of impregnated
asbestos.

Covering Smoothly lacquered glass-braid, Page 24.

Standard Flexible Cord and Fixture Wire.

Instructions Same as for Type AF Wire.
to
Inspector

* Northbrook (4) Same as for Type AF Wire
Counter-Check * (4) Flexibility, Page 48.
Program

* Marking General, Page 13.
*

* Temperature marker, Pages 18, 19, 20.
*

*Use Wiring of lampholders only.