CYANAMID

3/14 CC SAH

Fill 11.2

To: J. B. Reid

Date: March 4, 1988

Location: Wayne

Copy to: J. C. Caporossi - NA
J. F. Terenzi - NA
Plant Managers
Plant Industrial Hygiene Coordinators

From: N. D. Yin

Location: Wayne

Extension: 2708

Subject: ASBESTOS UPDATE - CHEMICALS GROUP

Reference:

PLAINTIFF'S EXHIBIT

ACC-20

Identification of asbestos in all Chemicals locations was initiated in 1984. To date, out of the total 415 buildings in Chemicals locations, 176 (42%) have been identified as containing asbestos. Of the remaining buildings, 177 have no asbestos and 62 have yet to be surveyed. 80 (45%) of 176 buildings containing asbestos have been monitored for airborne levels and results showed all are below the OSHA action level of 0.1 fibers/c.c. (See attachment). Completion of asbestos survey for the remaining 62 buildings is scheduled by 12/31/89.

Please present the Chemicals Asbestos Standard to the Environmental Committee for approval. The implementation of this standard will minimize accidental exposure to asbestos.

N. D. Yin

NDY:ml
08/3447J

A. W. DELGADO
MAR 14 1988

0159

NA 839-03 REV 7-85 7-85

CHEMICALS LOCATIONS ASBESTOS UPDATE AS OF 2/29/88

Plant	# Buildings (Production and Non-Production) # Containing Asbestos	# With no Asbestos	# To be Surveyed for Asbestos	# Total	# Monitored* for Airborne Level
Andersonville	0	9	0	9	-
Azusa	2	7	0	9	2
Benton	0	6	0	6	-
Charlotte	0	7	0	7	-
Chattanooga	0	6	0	6	-
Cloquet	0	1	0	1	-
Coosa Pines	0	4	0	4	-
DeRidder	0	1	0	1	-
Escanaba	1	0	0	1	1
Fortier	48	15	0	63	63
Georgetown	1	0	0	1	0
Hamilton	1	0	0	1	0
Havre de Grace	2	0	0	2	0
Joliet	1	1	0	2	1
Kalamazoo	1	3	0	4	0
Longview	1	6	0	7	0
Marietta	7	0	0	7	0
Michigan City	3	3	1	7	0
Mobile	4	7	0	11	0
Monticello	0	3	0	3	-
Niagara	3	24	0	27	0
Perrysburg	3	1	0	4	0
Plymouth	1	0	0	1	1
Santa Rosa	4	0	9	13	4
Saugus	0	8	0	8	-
Shippan	0	4	0	4	-
Stamford	10	0	5	15	1
Wallingford	19	21	0	40	2
Warners	14	3	0	17	1
Welland	15	20	20	55	0
Willow Island	26	11	27	64	0
Woodbridge	9	4	0	13	4
Woodbury	0	2	0	2	-
	176	177	62	415	80

* All area exposures monitored in the affected building are below OSHA action level of 0.1 fibers/c.c. TWA. (Current OSHA permissible limit for asbestos is 0.2 fibers/c.c.).

NDY:ml
08/3447J