TO: Shoals, ID, N. Langlie

December 2, 1986

FROM: #151, Libertyville, C. D. Byers

SUBJECT: INSULATION SAMPLES - AR 1552

PLAINTIFF'S EXHIBIT

USG-1482

Three insulation samples were received in Ziploc® plastic bags for analysis of fibrous components. Each bag contained one sample and was labeled. The fibrous components were analyzed by polarized light microscopy using dispersion staining. The results are as follows:

SAMPLE NO.	SAMPLE LABEL	FIBROUS COMPONENTS
1	Intermediate Return Plenum (Air Addition)	Asbestos (Chrysotile) Mineral Wool
2	Dry End Return	Asbestos (Chrysotile) Mineral Wool
3	Dry End Exhaust Duct Work	Asbestos (Chrysotile) Mineral Wool

CDB:tds
cc: #143, M. F. O'Toole
#176-5, J. R. Rabe
#151, B. W. Ost
#176-5, F. P. May

CS019 2035

6510 Rev. 4/85