TABLE 4. WEIGHTS OF SATURATED AND PARTLY SATURATED AIR FOR VARIOUS BAROMETRIC AND HYGROMETRIC CONDITIONS.[b]

Pounds per Cubic Foot

Dry-Bulb Temperature Deg F	Barometric Pressure—Inches																Approx. Average Increase in Weight per Deg Wet-Bulb Depression
	26			27			28			29			30				
	Wt. per Cu Ft Saturated Air	Decr'e Wt. per Deg Inc. Dry-Bulb	Incr'e Wt. per 0.1" Rise in Bar.	Wt. per Cu Ft Saturated Air	Decr'e Wt. per Deg Inc. Dry-Bulb	Incr'e Wt. per 0.1" Rise in Bar.	Wt. per Cu Ft Saturated Air	Decr'e Wt. per Deg Inc. Dry-Bulb	Incr'e Wt. per 0.1" Rise in Bar.	Wt. per Cu Ft Saturated Air	Decr'e Wt. per Deg Inc. Dry-Bulb	Incr'e Wt. per 0.1" Rise in Bar.	Wt. per Cu Ft Saturated Air	Decr'e Wt. per Deg Inc. Dry-Bulb	Incr'e Wt. per 0.1" Rise in Bar.	
0	0.07500	0.00016	0.00029	0.07788	0.00016	0.00029	0.08077	0.00017	0.00029	0.08365	0.00018	0.00029	0.08654	0.00019	0.00029	0.000015
10	0.07338	0.00016	0.00028	0.07620	0.00016	0.00028	0.07903	0.00017	0.00028	0.08185	0.00018	0.00028	0.08468	0.00018	0.00028	0.000016
20	0.07180	0.00016	0.00028	0.07456	0.00016	0.00028	0.07733	0.00017	0.00028	0.08009	0.00018	0.00028	0.08286	0.00018	0.00028	0.000017
30	0.07027	0.00015	0.00027	0.07297	0.00016	0.00027	0.07569	0.00016	0.00027	0.07839	0.00017	0.00027	0.08110	0.00017	0.00027	0.000019
40	0.06879	0.00015	0.00026	0.07143	0.00015	0.00027	0.07409	0.00016	0.00027	0.07675	0.00016	0.00027	0.07942	0.00017	0.00027	0.000021
50	0.06732	0.00015	0.00026	0.06992	0.00015	0.00026	0.07252	0.00016	0.00026	0.07512	0.00016	0.00026	0.07773	0.00016	0.00026	0.000023
60	0.06588	0.00015	0.00026	0.06843	0.00015	0.00026	0.07098	0.00015	0.00026	0.07353	0.00016	0.00026	0.07609	0.00016	0.00026	0.000026
70	0.06442	0.00015	0.00025	0.06692	0.00015	0.00025	0.06943	0.00015	0.00025	0.07193	0.00016	0.00025	0.07440	0.00016	0.00025	0.000029
80	0.06297	0.00015	0.00025	0.06542	0.00015	0.00025	0.06789	0.00015	0.00025	0.07034	0.00015	0.00025	0.07280	0.00016	0.00025	0.000034
90	0.06146	0.00015	0.00024	0.06388	0.00016	0.00024	0.06629	0.00016	0.00024	0.06870	0.00016	0.00024	0.07112	0.00017	0.00024	0.000039
100	0.05991	0.00016	0.00024	0.06228	0.00016	0.00024	0.06465	0.00016	0.00024	0.06703	0.00017	0.00024	0.06939	0.00018	0.00024	0.000044
110	0.05828	0.00016	0.00023	0.06060	0.00017	0.00023	0.06293	0.00017	0.00023	0.06526	0.00018	0.00023	0.06759	0.00019	0.00023	0.000051
120	0.05653	0.00018	0.00023	0.05882	0.00018	0.00023	0.06111	0.00018	0.00023	0.06339	0.00019	0.00023	0.06569	0.00020	0.00023	0.000059
130	0.05467	0.00019	0.00023	0.05692	0.00019	0.00023	0.05917	0.00019	0.00023	0.06142	0.00020	0.00023	0.06367	0.00022	0.00023	0.000068
140	0.05262	0.00021	0.00022	0.05483	0.00021	0.00022	0.05704	0.00021	0.00022	0.05925	0.00022	0.00022	0.06147	0.00024	0.00022	0.000078
150	0.05036	0.00023	0.00022	0.05253	0.00023	0.00022	0.05471	0.00023	0.00022	0.05689	0.00024	0.00022	0.05906	0.00026	0.00022	0.000090
160	0.04788	0.00025	0.00022	0.05001	0.00025	0.00022	0.05216	0.00026	0.00021	0.05430	0.00026	0.00021	0.05644	0.00029	0.00021	0.000103
170	0.04509	0.00028	0.00021	0.04720	0.00028	0.00021	0.04931	0.00029	0.00021	0.05141	0.00031	0.00021	0.05352	0.00033	0.00021	0.000118
180	0.04197	0.00031	0.00021	0.04404	0.00031	0.00021	0.04611	0.00032	0.00021	0.04818	0.00034	0.00021	0.05026	0.00036	0.00021	0.000134
190	0.03845	0.00035	0.00021	0.04049	0.00036	0.00021	0.04253	0.00036	0.00021	0.04457	0.00037	0.00021	0.04662	0.00038	0.00021	0.000153
200	0.03449	0.00040	0.00020	0.03650	0.00040	0.00020	0.03851	0.00040	0.00020	0.04052	0.00041	0.00020	0.04254	0.00041	0.00020	0.000173

[a] From *Fan Engineering*.

[b] A convenient and accurate chart for quickly determining the weight of air under any condition of dry-bulb, wet-bulb, and pressure is *A Chart for Determining the Weight of Moist Air in Pounds per Cubic Foot*, by John E. Younger. Published in *Mechanical Engineering*, June, 1925.

Table 4 is intended to aid in determining the density of moist air, taking into account its temperature, pressure, and moisture content.

Example 1. To show the use of Table 4: Given air at 83 F dry-bulb and 68 F wet-bulb (or a depression of 15 deg) with a barometric pressure of 29.40 in. of mercury. What will be the weight of this air in pounds per cubic foot?

Solution. From Table 4 the weight of saturated air at 80 F and 29.00 in. barometer is found to be 0.07034 lb per cubic foot. There is a decrease of 0.00015 lb per degree dry-bulb temperature above 80 F. There is an increase of 0.00025 lb for each 0.1 in. above 29.00 in. From the last column of Table 4 it is found that there is an increase of approximately 0.000035 lb per degree wet-bulb depression when the dry-bulb is 83 F. Tabulating the items:

0.07034 = weight of saturated air at 80 F and 29.00 bar.
− 0.00045 = decrement for 3 deg dry-bulb, 3 × 0.00015.
+ 0.00100 = increment for 0.4 in. bar., 4 × 0.00025.
+ 0.00053 = increment for 15 deg wet-bulb depression, 15 × 0.000035.
0.07142 = weight in pounds per cubic foot of air at 83 F dry-bulb, 68 F wet-bulb, 29.40 in. bar.

It is usual to assume that dry air, moist air, and the water vapor in the air follow the laws of perfect gases. This assumption while not absolutely true, especially with saturated vapor at temperatures much above 140 F, is sufficiently accurate for practical purposes and it greatly simplifies computations.

Boyle's Law refers to the relation between the pressure and volume of a gas, and may be stated as follows: *With temperature constant, the volume of a given weight of gas varies inversely as its absolute pressure.* Hence, if P_1 and P_2 represent the initial and final absolute pressures, and V_1 and V_2 represent corresponding volumes of the same mass, say one pound of gas, then $\frac{V_1}{V_2} = \frac{P_2}{P_1}$, or $P_1 V_1 = P_2 V_2$, but since $P_1 V_1$ for any given case is a definite constant quantity, it follows that the product of the absolute pressure and volume of a gas is a constant, or $PV = C$, when T is kept constant. Any change in the pressure and volume of a gas at constant temperature is called an *isothermal change.*

Charles' Law refers to the relation among pressure, volume, and temperature of a gas and may be stated as follows: *The volume of a given weight of gas varies directly as the absolute temperature at constant pressure, and the pressure varies directly as the absolute temperature at constant volume.* Hence, when heat is added at constant volume, V_c, the resulting equation is $\frac{P_2}{P_1} = \frac{T_2}{T_1}$, or, for the same temperature range at constant pressure, P_c, the relation is $\frac{V_2}{V_1} = \frac{T_2}{T_1}$.

In general, for any weight of gas, W, since volume is proportional to weight, the relation among P, V, and T is

$$PV = WRT \qquad (3)$$

where

P = the absolute pressure of the gas, pounds per square foot.
V = the volume of the weight W, cubic feet.