

above. This reduction in estimated amount is to take care of probable use. Thus, if 100 gal. are used on each floor of a 10-story building the size or pipe will be determined as in Table 2:

The pressure drop of 30 lb. per 100 ft. of run will give satisfactory results for branches on the top floor but a higher pressure drop can be used on floors below corresponding with the pressures as given in Table 5 which show that for a building 100 ft. in height, a pressure drop of 100 lb. can be used on the fixture lowest branches and that for a building 50 ft.

TABLE 1. COLD WATER BRANCH SUPPLY SIZES FOR FIXTURES AND MAXIMUM FLOW IN GALLONS PER MINUTE

	NUMBER OF FIXTURES									
	1	2	4	8	12	16	24	32	40	
Water Closets—										
Gal. per Min.	8	16	24	48	60	80	96	128	150	Tanks
Pipe Size	1/2	3/4	1	1 1/4	1 1/2	1 3/4	2	2 1/2	3	Flush
Gal. per Min.	30	50	80	120	140	160	200	250	300	Valves
Pipe Size	1	1 1/4	1 1/2	2	2	2	2 1/2	2 3/4	3	
Urinals—										
Gal. per Min.	6	12	20	32	42	56	72	90	120	Tanks
Pipe Size	1/2	3/4	1	1 1/4	1 1/2	1 3/4	2	2	2	Flush
Gal. per Min.	25	37	45	75	85	100	125	150	175	Valves
Pipe Size	1	1 1/4	1 1/2	1 3/4	2	2	2	2	2	
Lavatories and Wash Sinks—										
Based upon Each Faucet										
Gal. per Min.	4	8	12	24	30	40	48	64	75	
Pipe Size	1/2	3/4	1	1 1/4	1 1/2	1 3/4	2	2 1/4	2 1/2	
Bath Tubs—										
Gal. per Min.	15	30	40	80	96	112	144	192	240	
Pipe Size	3/4	1	1 1/4	1 1/2	2	2	2 1/4	2 1/2	2 3/4	
Shower Baths—										
Gal. per Min.	8	16	32	64	96	128	192	256	320	8" rain
Pipe Size	1/2	3/4	1	1 1/4	1 1/2	2	2 1/4	2 1/2	3	Head
Acid and Slop Sinks, Manufacturing,										
Kitchen and Laundry—										
Gal. per Min.	15	25	40	64	84	96	120	150	200	per bibb
Pipe Size	3/4	1	1 1/4	1 1/2	2	2	2	2 1/4	2 1/2	per bibb

Note.—The above sizes are based upon a pressure drop of 30 lb. per 100 ft.

In estimating risers and mains, the number of gallons for W. C. and urinals where flush valves are used are to be as given for tanks.

The hot-water faucets are to be disregarded when estimating cold-water risers and mains.

in height, a pressure drop of 52 lb. can be used on the lowest fixture branches; Table 1, however, can be used with safety on any of the floors but will give pipe sizes larger than necessary for the lower floors in a very tall building.

Table 5 gives the amount of water in gallons which may be passed through pipes of 3/4 in. to 4 in. diameter with pressure drop from 5 lb. to 150 lb. per 100 ft. of run. This table may be used in sizing horizontal and vertical mains.

For example, if the water main pressure available is known, say 90 lb., and the horizontal run from water main to vertical riser is 100 ft., and the vertical riser is 100 ft. to top branch; it will require 43.31 lb. for static head (see Table 6), and 15 lb. pressure at a minimum should be allowed for the uppermost fixture or a total of 58.31 lb. which would leave available for friction 90—58.31=31.69 for friction in 200 ft. run, or

8.34 lb. per 100 ft. The main can thus be sized from the 7 lb. pressure drop of Table 5.

TABLE 2. WATER RISERS FOR MANUFACTURING BUILDINGS, LOFT BUILDINGS, APARTMENT HOUSES, HOTELS

	G. P. M.	G. P. M.	PIPE SIZE WITH DROP PER 100 FT. RUN		
			5 lb.	10 lb.	20 lb.
10th Floor	100 x 0.60	60% = 60	2"	2"	1 1/2"
10 and 9	200 x 0.60	90% = 108	2 1/2"	2 1/2"	1 1/2"
10 and 9 and 8	300 x 0.60	80% = 144	3"	2 1/2"	2"
10 to 7 incl.	400 x 0.60	70% = 168	3 1/2"	3"	2 1/2"
10 " 6 "	500 x 0.60	60% = 180	3 1/2"	3"	2 1/2"
10 " 5 "	600 x 0.60	50% = 180	3 1/2"	3"	2 1/2"
10 " 4 "	700 x 0.60	40% = 184	3 1/2"	3"	2 1/2"
10 " 3 "	800 x 0.60	40% = 192	3 1/2"	3"	2 1/2"
10 " 2 "	900 x 0.60	40% = 216	3 1/2"	3"	2 1/2"
10 " 1 "	1000 x 0.60	40% = 240	3 1/2"	3"	2 1/2"

Note.—For residences, use Table 1, and for the main supply use 25 per cent of total of gallons used by fixtures and then take pipe size from Table 5 on a basis of 10 lb. pressure drop per 100 ft. or less if water supply pressure is less than 50 lb.

TABLE 3. APARTMENT HOUSE SUPPLY RISERS
Based upon One, Two, and Three Baths per Apartment

ONE (1) BATH APARTMENT		TWO (2) BATH APARTMENT		THREE (3) BATH APARTMENT	
1 bath	15 gal.	2 baths	24 gal.	3 baths	30 gal.
1 W. C.	8 gal.	2 W. C.	14 gal.	3 W. C.	18 gal.
1 sink	4 gal.	1 sink	4 gal.	1 sink	4 gal.
1 lav.	4 gal.	2 lavs.	6 gal.	3 lavs.	9 gal.
	31 gals.		48 gals.		61 gals.
50% demand—15 gals. per min.		40%—20 gals. per min.		40%—24 gals. per min.	
	Riser		Riser		Riser
Top Floor	15 gal.	20 gal.	1 1/4"	24 gal.	1 1/4"
Next	28 "	38 "	1 1/2"	43 "	2"
"	38 "	54 "	2"	64 "	2"
"	51 "	68 "	2"	82 "	2"
"	60 "	80 "	2"	96 "	2 1/2"
"	67 "	90 "	2"	108 "	2 1/2"
"	71 "	98 "	2 1/2"	117 "	2 1/2"
"	78 "	104 "	2 1/2"	124 "	2 1/2"
"	81 "	108 "	2 1/2"	134 "	2 1/2"
"	83 "	110 "	2 1/2"	143 "	2 1/2"
"	84 "	110 "	2 1/2"	143 "	2 1/2"
"	85 "	110 "	2 1/2"	143 "	2 1/2"

Note.—The pipe sizes are based upon a drop of 10 lb. water pressure for each 100 ft. run. The size of branch for each Apartment should be not less than 1 1/4 in.

Example—What is the riser size needed for a six-story apartment house having one bath for each apartment?

Table 3 gives 2 in. diameter for all from four to twelve stories with 1 1/4 in. to supply the top floor and next to top and 1 1/2 in. for floor below.

What is the size of riser needed for a twelve-story apartment house with three baths to each apartment?

Table 3 gives 2 1/2 in. for all floors up to eighth floor, 2 in. for ninth, tenth and eleventh, and 1 1/4 in. for top floor.

What is the riser size for a two bath apartment six stories high?

Table 3 gives 2 in. for the first four floors with 1 1/2 in. at fifth floor and 1 1/4 in. on the top floor.