

American Society of Heating and Ventilating Engineers

29 West 39th Street, New York

THE CODE OF MINIMUM REQUIREMENTS

for the

HEATING AND VENTILATION OF BUILDINGS

(Edition of 1929)

\$5.00 per Copy

The Code has been recently published by the AMERICAN SOCIETY OF HEATING AND VENTILATING ENGINEERS, New York, in fourteen sections, bound attractively in a loose leaf holder.

Each section was prepared by a Subcommittee and the following subjects are covered:

Section I—Minimum Ventilation Requirements for Public Buildings.

Section II—Minimum Requirements for Estimating the Heat Required for Warm Buildings.

Section III—Minimum Requirements for the Determination of the Amount of Direct Steam and Hot Water Radiating Surface to be installed in Steam and Hot Water Heating Systems.

Section IV—Minimum Requirements for the Determination of the Amount of Indirect Steam or Hot Water Heating Surface to be installed in Indirect Gravity and Fan Circulation Heating and Ventilating Systems.

Section V—Minimum Capacity and Installation Requirements for Low Pressure Steam and Hot Water Heating Boilers.

Section VI—Minimum Requirements for the Design and Installation of Warm Air Furnace Heating Plants.

Section VII—Minimum Requirements for the Design and Installation of Chimneys or Stacks for Steam Boilers, Hot Water Boilers and Warm Air Furnaces.

Section VIII—Minimum Requirements for Pipe Sizes for Use with Low Pressure Steam, Vapor and Vacuum Heating Systems.

Section IX—Minimum Requirements for Pipe Sizes for Use with Gravity and Forced Hot Water Heating Systems.

Section X—Minimum Requirements for the Design and Installation of Air Ducts, Inlets and Outlets, in Conjunction with Fan Air Circulation, and the Installation of Ventilating Fans for Use with Steam and Hot Water Heating and Ventilating Systems.

Section XI—Minimum Requirements for the installation of Air Washers and Filters.

Section XII—Pumps for Heating and Ventilating Equipment.

Appendix I—Formulae for Physical Units, Air and Vapor Mixtures, Etc.

Appendix II—Standard Symbols for Heating and Ventilating Drawings.

The Code consists of 158 pages and is fitted into a loose leaf binder with black flexible cover. It is printed on India Tint stock, 6 x 9 inches in size.

The Code of Minimum Requirements was developed as a result of numerous requests made to the Society by engineers, architects, municipalities, engineering and trade organizations and its purpose is to standardize as far as practical the installation of heating and ventilating equipment.

The Code represents minimum requirements as called for by good engineering practice and is so written that it may be incorporated as a part of a Municipal Building Code, if found desirable.

American Steam Pump Company


Plant and General Offices: Battle Creek, Michigan

NEW YORK: 17 BATTERY PLACE
CHICAGO: 926 MONADNOCK BLDG.



SALES AND SERVICE AGENCIES
THROUGHOUT THE WORLD

Manufacturers of High Grade Centrifugal Steam and Power Driven Pumps of all Approved Types to Meet Every Industrial and Public Building Requirement




American-Marsh Centrifugal Pumps
—New Type HL Single Stage Centrifugal Pumps, shown above cost less to run, due to higher efficiencies and ball bearings (standard equipment). Furnished with bronze seal rings, bronze impellers hydraulically balanced, and split cases. Ideal for hot or cold water circulating, low pressure boiler feed, air washer service, etc. Designed with non-overloading characteristic and many other important features. BULLETIN 61.

Also other centrifugal pumps in all approved types, both single and multi-stage, split or solid case. Adaptable to any liquid handling job with sizes to meet all needs. BULLETINS 25, 38 and 53.

American-Marsh Condensation Pumps and Receivers—Both steam and centrifugal motor driven types in sizes to meet all requirements. Furnished complete with control equipment. BULLETINS 27 and 32.


American-Marsh Steam Pumps—Both simplex and duplex types in sizes to cover any liquid handling requirement, such as boiler feed, tank filling, etc. Bronze fitted throughout. 225,000 units in service. BULLETINS 26 and 28.




Multistage Centrifugal Pump

American-Marsh Sump Pumps:—

Designed for automatic operation, elevating sewage and drainage to sewer levels, for cellar drains, etc. Current used only when pump runs; pump always submerged ready to start. Sizes to handle all jobs. Simple design for faithful service without attention. Also built as duplex units, similar in construction except that two complete pumps are mounted on one cover plate. BULLETIN 41.



Sump Pump



Steam Vacuum Pump

American-Marsh Vacuum Pumps:—Standard equipment includes bronze fittings throughout. Designed for all vacuum heating needs with sizes to handle up to 200,000 sq. ft. radiation. Motor driven if desired. BULLETIN 24.

Guarantees and Engineering Service:—Every pump is rigidly tested and guaranteed to meet conditions specified. It is further guaranteed against any defects in material and workmanship. Write for the co-operation of our engineers. Our forty years' experience is at your disposal.