



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 6

1445 ROSS AVENUE SUITE 1200

DALLAS TEXAS 75202-2733

August 3, 1990

REPLY TO: 6W-EAO

Mr. T. G. Brown, Works Manager
PPG Industries
P.O. Box 1000
Lake Charles, Louisiana 70602

Re: NPDES Permit No. LA0000761

Dear Mr. Brown:

We note that your facility is in violation of the above referenced permit, specifically, the following violations:

<u>Date</u>	<u>Outfall</u>	<u>Parameter</u>	<u>Violation</u>	<u>Permit Limit</u>
03/14/90	001	pH, max.	9.9 s.u.	9.0 s.u.
04/24/90	001	pH, max.	9.6 s.u.	9.0 s.u.
04/17/90	201	TRC, max.	784.7 lbs.	37.7 lbs.
04/90	201	TRC, avg.	57.5 lbs.	22.9 lbs.
05/31/90	201	TSS, max.	134.35 lbs.	114.65 lbs.

Your facility should take whatever remedial action is necessary to prevent the recurrence of the violations noted above.

A report of the above violations will be placed in your file. The report will be used in our consideration of the appropriate action to be taken in the event of future violations. Future enforcement actions could include administrative compliance orders, administrative penalty orders, and/or referral to the United States Department of Justice for judicial action with monetary fines.

If you have any questions, please contact me at the above address or telephone (214) 655-6455.

Sincerely yours,

Diana Buck

Diana Buck
Environmental Assistant
Enforcement Branch (6W-EAO)

cc: Mr. Tom Killeen
Enforcement Program Manager
Louisiana Department of Environmental Quality

SL 026654