

TABLE 9. COEFFICIENTS OF TRANSMISSION (*U*) OF CONCRETE CONSTRUCTION FLOORS AND CEILINGS^a
Coefficients are expressed in *Btu per square foot per degree Fahrenheit difference in temperature between the air on the two sides,*
and are based on still air (no wind) conditions on both sides.

TYPICAL CONSTRUCTION	THICKNESS OF CONCRETE (INCHES)	No.	TYPE OF FLOORING				
			No Flooring (Concrete Bare) ^a	Yellow Pine Wood Sleepers Embedded in Concrete ^a	Maple or Oak Flooring on Yellow Pine Sub-Flooring ^a on Wood Sleepers Embedded in Concrete	Tile or Terrazzo Flooring on Concrete	1/4-in. Battlement Linoleum Directly on Concrete
			A	B	C	D	E
No Ceiling	4	1	0.65	0.40	0.31	0.61	0.44
	6	2	0.59	0.37	0.30	0.56	0.41
	8	3	0.53	0.35	0.28	0.51	0.38
	10	4	0.49	0.33	0.27	0.47	0.36
1/2 in. Plaster Applied Directly to Under Side of Concrete	4	5	0.59	0.38	0.30	0.56	0.41
	6	6	0.54	0.35	0.28	0.52	0.38
	8	7	0.50	0.33	0.27	0.47	0.36
	10	8	0.45	0.32	0.26	0.44	0.34
Suspended or Furred Metal Lath and Plaster (3/4 in.) Ceiling	4	9	0.37	0.28	0.23	0.36	0.29
	6	10	0.35	0.26	0.22	0.34	0.28
	8	11	0.33	0.25	0.21	0.32	0.27
	10	12	0.32	0.24	0.21	0.31	0.25
Suspended or Furred Ceiling of Plaster Board (3/4 in.) and Plaster (1/2 in.)	4	13	0.35	0.26	0.22	0.34	0.28
	6	14	0.33	0.25	0.21	0.32	0.26
	8	15	0.31	0.24	0.21	0.30	0.25
	10	16	0.30	0.23	0.20	0.29	0.24
Suspended or Furred Ceiling of Rigid Insulation (1/2 in.) and Plaster (1/2 in.)	4	17	0.24	0.20	0.17	0.24	0.21
	6	18	0.23	0.19	0.17	0.23	0.20
	8	19	0.22	0.18	0.16	0.22	0.19
	10	20	0.22	0.18	0.16	0.21	0.19
Plaster (1/2 in.) on Corkboard (1 1/2 in.) Set in Cement Mortar (1/2 in.) on Concrete	4	21	0.15	0.13	0.12	0.14	0.14
	6	22	0.14	0.13	0.12	0.14	0.13
	8	23	0.14	0.12	0.11	0.14	0.13
	10	24	0.14	0.12	0.11	0.14	0.13

^aComputed from factors marked by * in Table 2.

^bThe figures in Column A may be used with sufficient accuracy for concrete floors covered with carpet.

^cThe figures in Column B may be used with sufficient accuracy for concrete floors covered with carpet.

^dThe figures in Column C may be used with sufficient accuracy for maple or oak flooring^e applied directly over the concrete on wood sleepers.

^eThickness of maple or oak flooring assumed to be 1/4 in.

^fThickness of tile or terrazzo assumed 1 in.

TABLE 10. COEFFICIENTS OF TRANSMISSION (*U*) OF CONCRETE FLOORS ON GROUND WITH VARIOUS TYPES OF FINISH FLOORINGS.^a
Coefficients are expressed in *Btu per square foot per degree Fahrenheit difference in temperature between the ground and the air over the floor,*
and are based on still air (no wind) conditions.

TYPICAL CONSTRUCTION	THICKNESS OF CONCRETE (INCHES)	No.	TYPE OF FINISH FLOORING				
			No Flooring (Concrete Bare)	Yellow Pine Flooring ^a on Wood Sleepers Resting on Concrete	Maple or Oak Flooring ^a on Yellow Pine Sub-Flooring on Wood Sleepers Resting on Concrete	Tile or Terrazzo ^d on Concrete	1/4-in. Battlement Linoleum Directly on Concrete
	4	1	1.07	0.35	0.28	0.98	0.60
	6	2	0.90	0.33	0.27	0.84	0.54
	8	3	0.79	0.32	0.26	0.74	0.50
	10	4	0.70	0.30	0.25	0.66	0.46
None	4	5	0.66	0.29	0.24	0.63	0.44
	8	6	0.54	0.27	0.23	0.52	0.39
None	4	7	0.22	0.16	0.14	0.22	0.19
	8	8	0.21	0.15	0.13	0.20	0.18
	4	9	0.12	0.099	0.093	0.12	0.11
	8	10	0.12	0.096	0.090	0.12	0.11

^aComputed from factors marked by * in Table 2.

^bAssumed 1/4 in. thick.

^cAssumed 1/4 in. thick.

^dAssumed 1 in. thick.

^eThe figures for Nos. 5 to 10, inclusive, include 3-in. cinder concrete placed directly on the ground. The insulation is applied between the cinder concrete and the stone concrete. Usually the insulation is protected on both sides by a waterproof membrane, but this is not considered in the calculations.