

water in certain parts of the system until the steam flow is reduced sufficiently to permit the water to pass. The velocity at which such disturbances take place is a function of (1) the pipe size, whether the pipe runs horizontally or vertically, (2) the pitch of the pipe if it runs horizontally, (3) the quantity of condensate flowing against the steam, and (4) freedom of the piping from water pockets which under certain conditions act as a restriction in pipe size.

Three factors of uncertainty always exist in determining the capacity of any steam pipe. The first is variation in manufacture, which apparently cannot be avoided and which caused an actual difference of 20 per cent in the capacity of a 1-in. pipe in experiments carried on at the A.S.H.V.E. Research Laboratory (Table 5). The second is the reaming of the ends of the pipe after cutting, which, experiments indicate, might reduce the capacity of a 1-in. pipe as much as 28.7 per cent (Table 6). The third is the uniformity in grading the pipe line. All of the capacity tables given in this chapter include a factor of safety. However, the pipe

TABLE 4. COMPARATIVE CAPACITY OF STEAM LINES AT VARIOUS PITCHES FOR STEAM AND CONDENSATE FLOWING IN OPPOSITE DIRECTIONS^a

Pitch of Pipe in Inches per 10 Ft

Pitch of Pipe	1/4 IN.	1/2 IN.	1 IN.	1 1/2 IN.	2 IN.	3 IN.	4 IN.	5 IN.
Pipe Size Inches	Sq Ft Rad. Based on 240 Btu	Max. Vel.	Sq Ft Rad. Based on 240 Btu	Max. Vel.	Sq Ft Rad. Based on 240 Btu	Max. Vel.	Sq Ft Rad. Based on 240 Btu	Max. Vel.
1/4	25.0	12	30.3	14	37.3	18	40.4	19
1/2	45.8	12	52.6	15	63.0	17	70.0	20
3/4	104.9	18	117.2	20	135.0	23	144.5	25
1	142.6	18	159.0	21	181.0	23	196.5	25
1 1/4	236.0	19	263.5	20	299.5	23	325.5	25
1 1/2								
2								

^aData from AMERICAN SOCIETY OF HEATING AND VENTILATING ENGINEERS Research Laboratory.

on which Table 5 is based showed no particular defects or constrictions on the inside, and the factor of safety referred to does not cover abnormal defects or constrictions *nor does it cover pipe not properly reamed.*

Equivalent Length of Run

All tables for the flow of steam in pipes, based on pressure drop, must allow for the friction offered by the pipe as well as for the additional resistance of the fittings and valves. These resistances generally are stated in terms of straight pipe; in other words, a certain fitting will produce a drop in pressure equivalent to so many feet of straight run of the same size of pipe. Table 7 gives the number of feet of straight pipe usually allowed for the more common types of fittings and valves. In all pipe sizing tables in this chapter the *length of run* refers to the *equivalent length of run* as distinguished from the *actual length* of pipe in feet. The length of run is not usually known at the outset; hence it is necessary to assume some pipe size at the start. Such an assumption frequently is considerably in error and a more common and practical method is to assume the length of run and to check this assumption after the pipes are sized. For this purpose the length of run usually is taken as double the actual length of pipe.

TABLE 5. PER CENT DIFFERENCE IN CAPACITY FOR CARRYING STEAM AND CONDENSATE DUE TO VARIATION OF PIPE SIZE AND SMOOTHNESS^a

Size of pipe	MAXIMUM CONDENSATION, LB PER HOUR			
	3/4 In.	1 In.	1 1/4 In.	1 1/2 In.
Minimum	14.00	24.89	45.42	70.50
Maximum	15.20	30.08	52.08	82.00
Per cent variation	8.6	20.8	14.7	16.3

^aData from AMERICAN SOCIETY OF HEATING AND VENTILATING ENGINEERS Research Laboratory.

TABLE 6. EFFECT OF REAMING ENTRANCE TO ONE-INCH ONE-PIPE RISERS^a

	MAXIMUM CAPACITY OF RISER	PER CENT DECREASE
Reamed entrances	24.7 lb per hour	0.0
Rounded entrances	23.9 lb per hour	3.2
Squared entrances	22.2 lb per hour	10.1
Three wheel cutter	19.2 lb per hour	22.2
Single wheel cutter	17.6 lb per hour	28.7

^aData from AMERICAN SOCIETY OF HEATING AND VENTILATING ENGINEERS Research Laboratory.

TABLE 7. LENGTH IN FEET OF PIPE TO BE ADDED TO ACTUAL LENGTH OF RUN—OWING TO FITTINGS—TO OBTAIN EQUIVALENT LENGTH

SIZE OF PIPE INCHES	ST'D. ELBOW	SIDE OUTLET TEE	GATE VALVE	GLOBE VALVE	ANGLE VALVE
	Length in Feet to be Added to Run				
2	5	16	2	18	9
2 1/2	7	20	3	25	12
3	10	26	3	33	16
3 1/2	12	31	4	39	19
4	14	35	5	45	22
5	18	44	7	57	28
6	22	50	9	70	32
7	26	55	10	82	37
8	31	63	12	94	42
9	35	69	13	105	47
10	39	76	15	118	52
12	47	90	18	140	63
14	53	105	20	160	72

Example of length in feet of pipe to be added to actual length of run.

