PLAINTIFF'S EXHIBIT

CT-1270

CertainTeed

Technical Bulletin

JPM NOT ON DIST. / NOT ON MY LIST

December 16, 1980

TO: All P&PG Sales and Marketing Personnel
District Sales Managers
Territory Managers
Sales Engineers
A/C Customer Service Managers
A/C Quality Control Managers

FR: James R. Alley James R Alley

SUBJECT: IAPMO - RECOMMENDATION OF PLUMBING RESEARCH COMMITTEE
ASBESTOS-CEMENT BUILDING SEWER PIPE 4", 5", & 6"

Attached is a copy of the Research Committee Approval. Product listing will appear in the Directory of Research Recommendations. Approval covers all classes of sewer pipe and fittings in the above sizes.

If you require additional copies, please contact the A/C Marketing Specification Engineer at Valley Forge

BULLETIN: A/C 38 DATE: 12/16/80

INTERNATIONAL ASSOCIATION OF PLUMBING AND MECHANICAL OFFICIALS

A NON-PROFIT CORPORATION

RECOMMENDATION OF THE PLUMBING RESEARCH COMMITTEE

The product described herein has been reviewed, tested and recommended for acceptance by the Research Committee of the International Association of Plumbing and Mechanical Officials as meeting the requirements of the UNIFORM PLUMBING CODE. This recommendation is subject to the conditions set forth in the characteristics below and is not to be construed as assurance or guarantee by the Association of product acceptance by local jurisdiction or authorities using the UNIFORM PLUMBING CODE or otherwise affiliated with the Association.

Accepted September 1980 Void after September 1981

PRODUCT: Sewer Pipe & Fittings (Asbestos Cement) FILE NO. 741

APPLICANT: Certain-Teed Products Corp.
Pipe and Plastics Group
P.O.Box 860
Valley Forge, PA 19482

MODEL: Fluid-Tite 4", 5", 6"

IDENTIFICATION: Manufacturer's name or trademark, size on both pipe and fittings.

CHARACTERISTICS: Asbestos - cement small diameter sewer pipe and fitting for conveying domestic sewage from the house or building to street or private disposal system. Pipe comes complete with couplings and gaskets in various minimum crushing strengths. Meets ASTM C 644 specifications.

This recommendation is for the period indicated herein and is void after date shown above. Any change in ... design without having first obtained the approval of the Research Committee or evidence of inferior work ... follow an equitable service policy may be deemed as sufficient cause for revocation of this recommend... reference to this form for advertising purposes may be made only by specific written permission of In... Plumbing and Mechanical Officials. This authorizes the use of the UPC shield on products covered by this ...

CHAIRMAN RESEARCH COMMITTEE (UPC) EXECUTIVE O...

Sponsor of Uniform Plumbing Code, Uniform Swimming Pool Code, Uniform Solar Energy Code and Uniform Mechanical Code

CTD000563