

WRITTEN BY:RLD
DATE:2/26/90

SOP 5603-069.SOP
(PLC III CONTROL LOOP NUMBERS)

LP-EDC RX PLC III CONTROL LOOP NUMBERS

<u>PLC NO.</u>	<u>LOOP NO.</u>	<u>SPAN</u>	<u>DESCRIPTION</u>
		CL₁	
4098	TT-1615	200 °F	CL ₂ SURGE DRUM INLET TEMP.
4099	TT-1617	200 °F	CL ₂ SURGE DRUM BOTTOM TEMP
4100	PT-1415	150 PSIG	EDC RX CL ₂ FEED PRESSURE
4101	FT-1020	220,000 SCFH	EDC RX CL ₂ FEED FLOW
4102	FT-1023	220,000 SCFH	EDC RX CL ₂ FEED FLOW
		C₂H₄	
4103	TT-1630		EDC RX C ₂ H ₄ FEED TEMP.
4104	PT-1430	150 PSIG	EDC RX C ₂ H ₄ FEED PRESSURE
4105	FT-1030	220,000 SCFH	EDC RX C ₂ H ₄ FEED FLOW
4106	FT-1033	220,000 SCFH	EDC RX C ₂ H ₄ FEED FLOW
		PRESSURE	
4107	PT-1455	50 PSIG	EDC RX. TOP PRESSURE
		C₂H₄ ANALYZERS	
4108	AIT-1980		C ₂ H ₄ ANALYZER #1
4109	AIT-1981		C ₂ H ₄ ANALYZER #2
		LEVELS	
4111	LT-1250	30 FEET	EDC RX. LEVEL
4112	LT-1255	30 FEET	EDC RX. LEVEL

SL 003852

CONFIDENTIAL
Subject to Protective Order
of 14th Judicial District Court
No. 91-1145