

Memorandum on General Asbestos and Rubber Plant of Raybestos-
Manhattan, Inc., Supplementing the General Report "Preliminary
Dust Investigation for Asbestos Textile Institute" of June, 1947.

Low and we would advise that arrangements be made with Dr. Fehnel for a
thoroughly complete survey without waiting for such changes. A liberal
number of samples in each operation is required to establish average
figures.

Dust counts made by us are as follows:

Number	Elapsed Time (Mins.)	Location	Dust Count
1	10	General air near take-off end of card, & machines distant from foreman's office.	0.2
2	10	In breathing zone of rule spinner opera- tory following him during sampling.	0.4
3	10	In breathing zone of operator of <u>texter</u> <u>winder</u> . (About 1/4 of duct branches plugged by bobbins.)	0.4
4	10	General air, taken while following with- in 6 to 7 feet of operator of <u>ring</u> <u>spinning frame</u> .	0.5
5	10	General air in vicinity of & exhausted <u>looms</u> (dry).	0.6
6	10	In breathing zone of operator of one <u>loom</u> .	0.3
7	10	General air, taken while walking up and down aisles of <u>printers</u> . Exhausted.	0.9
8	10	Same as No. 7, but exhaust system shut off.	1.8

JHM33022