

V

Vacuum

- cooling unit, 484
- heating pumps, 282
- control, 283
- piston displacement, 284
- heating systems, 276, 849
- down-feed, 278
- unit heater connection, 433

Vacuum dryer, 746

Valve, valves, 365

- angle, 366
- automatic, 365
- check, 365
- control, 364
- expansion, 488
- flow, 289
- gate, 365
- globe, 365
- reducing pressure, 301, 365

Vane, vanes, 593

Vaned outlets, 596

Vapor, vapors

- heating system, 850
- unit heater connection, 433
- pressure, 850

Vaporizing oil burner, 216

Velocity, 850

- exhaust grilles, 600
- method duct design, 616
- pressure, 850
- return grilles, 600

Ventilation, 850

- air conditioning units, 443
- dairy barn, 772
- garage, 773
- hospitals, 702
- natural, 765
- general rules, 771
- passenger bus in summer, 715
- physiological objectives of, 65
- railway passenger car, 711
- state codes, 882
- symbols for drawing, 859
- systems, 395
- wind forces, 765

Ventilator, ventilators

- roof, 770, 847
- unit, 435
- control, 662

Vertical blow unit heater, 428

Vertical openings, 126

- sealing of, 126

Vibration, machine, 641

- viscous filters, 566
- automatic, 567
- impingement, 566

Vitiation of air, 41

Volume

- control, 414
- furnace, 180
- specific, 848

W

Wall, walls

- heat flow through, 153
- heat transfer coefficients, 115
- infiltration through, 120
- time lag of solar radiation, 155

Warm air

- heating systems, 369, 383, 850
- method of cooling, 394
- panel heating, 807, 808
- radiant heating, 807
- radiators, 215

Washer, washers, 531

air, 843

Water

- atmospheric cooling equipment, 537
- coils, 506
- control temperature service, 389
- cooled
- condenser, 490
- unit conditioning, 445
- corrosion treatment, 368

heater

- coal-fired, 838
- solar, 840
- heating, 819, 835
- make-up, 553
- maximum, main temperature, 539
- properties of, 482
- supply piping, 819

allowance for fittings, 823

factor of usage, 820

maximum flow, 820

pressure, 821

sizing down-feed systems, 827

sizing up-feed systems, 825

thermodynamics of, 1

well, temperatures, 538

Water vapor, 6

saturation pressure, 6

specific enthalpy, 7

specific volume, 7

Welding, 345, 358

Wet-bulb temperature, 542, 850 (*see Temperature*)

Wet return, 850

Wind, winds

forces, 766

due to stack effect, 766

natural draft equipment, 545

selection of, velocity, 138

Window, windows

coefficients of transmission, 115

leakage, 121, 123

solar radiation through, 154, 155

ventilators, 439

Winter

air conditioning system, 395

comfort zone, 59

freezing, equipment, 537

Wound rotor motor, 689

Wrought-iron pipe, 345

Wrought-steel pipe, 345

X-Y-Z

Year 'round air conditioning system, 395

Zone control, 648

evaporative regulation, 50

Zoning, 412

control, 648

dual duct, 414


multiple fans, 413

recooling, 413

reheat, 413

separating equipment, 413

volume control, 414



Chapter I

THERMODYNAMICS OF AIR AND WATER MIXTURES

Dry Air, Specific Enthalpy, Water Vapor, Moist Air, Dalton's Law, Humidity Ratio, Relative Humidity, Dew-point, Enthalpy, Thermodynamic Wet-bulb Temperature, Mollier Diagram, Typical Air Conditioning Processes, Adiabatic Saturation, Psychrometric Chart, Steady Flow Energy Equation, U. S. Standard Atmosphere

THE working substance of the air conditioning engineer may be regarded, for the purpose of analysis, as a mixture of only two constituents, dry air and water. The mixture may consist of two, and possibly three distinct phases, solid, liquid and vapor. The vapor phase is conveniently referred to as *moist air* and is regarded as a mixture of *dry air* and *water vapor*.

DRY AIR

Composition. Dry air is itself a mixture of several gases, but its composition is subject to such slight variation that it may be regarded as fixed. According to *International Critical Tables*, the mol-fraction composition of dry air is given by the first column of figures in Table 1. Molecular weights are given in the second column; the last figure in the third column is the *apparent* molecular weight of the mixture; the fourth column of figures gives the ordinary weight-fraction composition.

It is well known that dry air contains other gases besides those listed in Table 1; but these are present in such minute amounts that they can be grouped together as argon. Values in the lower section of Table 1 give the approximate mol-fraction composition of what is called argon in the upper portion of the table.

In physical and chemical thermodynamics, there is a distinct advantage in using a different unit of weight, the mol, for each different substance involved. A mol of oxygen weighs 32.000 lb as a matter of definition; a mol of any other substance is a weight, in pounds, equal to its molecular weight.

Specific Volume and Density

The ratio of total volume to total weight is called *specific volume*, *v*. In the English system, volume is expressed in cubic feet and weight in pounds; hence, specific volume is expressed in cubic feet per pound. The reciprocal of specific volume, that is, weight per unit volume is called *weight density*, *d*. The unit of density is the pound per cubic foot.