



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 1

Laboratory Services and Applied Science Division
11 Technology Drive
North Chelmsford, Massachusetts 01863-2431

Drafted Date: 10/21/2020

Finalized Date: 11/03/2020

Subj: Inspection Report
Clean Water Act
Saveway Petroleum, Inc.

From: Jerome Keefe, SPCC Inspector //JCK
Field Services Branch (FSB)
Laboratory Services and Applied Science Division (LSASD)

To: Denny Dart, Water Compliance Branch Chief
Enforcement and Compliance Assurance Division (ECAD-EWC)

CC: Beth Kudarauskus, Inspector, ECAD-EWC
Joseph Canzano, Inspector, ECAD-EWC

I. Facility Information

A. Facility Name: Saveway Petroleum, Inc.

B. Facility Location: 906 CT-32
North Franklin, CT

C. Facility Contacts: Mr. David Scott (Treasurer), Mrs. Marna Marasco
(Secretary)(860) 774-6340

D. ID No(s): R1-CT-00217 (SPCC Oil Database #)

II. Background Information

A. Date(s) of inspection: August 27 - August 27, 2020

B. Weather Conditions: Cloudy and rain Temperature 72 degrees F

C. US EPA Representative(s): Jerome Keefe

D. State/Local Representative(s): None

E. Federally Enforceable Requirements Covered During the Inspection: 40 CFR part
112

F. Previous Enforcement Actions: None

III. Type and Purpose of Inspection

Public Roadside Inspection

IV. Disclaimer:

Unless otherwise noted, this report describes conditions at the facility/property as observed by EPA inspector(s), and/or through records provided to and/or information reported to EPA inspector(s) by facility representatives and as understood by the inspector(s). This report may not capture all operations or activities ongoing at the time of the inspection. This report does not make final determinations on potential areas of concern. Nothing in this report affects EPA's authorities under federal statutes and regulations to pursue further investigation or action.

V. Facility Description

Saveway Petroleum, Inc. stores oil products used for home heating, off road diesel, kerosine, gasoline, and propane. The company service areas are approximately Eastern CT and Worcester County, MA. They provide year-round and 24/7 oil delivery, installation, maintenance, and repair services to homeowners and commercial businesses through licensed technicians.

The company does not list a specific address for the main offices and a mailing address PO Box 900, Danielson, CT 06239 (Brooklyn, CT 06234). The Better Business Bureau (BBB) list the facility address as 49 South Main St, Danielson, CT 06239 which appears to be a service gas station. The BBB website shows the business starting in 1970 (company website says 1971) with an estimated 25 employees.

An article from Fuel Oil News website dated September 29, 2020 states that "DCC Propane of Roberts, Illinois, acquired the full-service energy business of NES Group, consisting of Northeast Oil and Propane, and Saveway Petroleum, Cetane Associates announced." The article goes on to say that the NES Group is headquartered in Brooklyn, Connecticut and that they sell, deliver, and provide propone services as well as have two bulk storage facilities.

VI. Inspection

The inspection was unannounced and no contact with the facility was made on August 27, 2020.

I arrived near the facility at approximately 1530. The weather conditions were cloudy with rain. The traffic in the area was heavy along Route 32.

The facility appears to have loading/unloading operations on-site. Surface water flow direction from the facility was observe going north towards Cold Brook. One storm drain was visible downgradient, north along Route 32 near Cold Brook. Pictures 1-4 show the flow of surface water from Saveway down towards Cold Brook (approximately 1000 ft). At the time of the drive-by four mobile refueler trucks were parked on site and had

Saveway logos (Photograph 6). The facility has two large bulk Above Ground Storage Tanks (AST's) (capacities are greater than 1320 gallons) with placards number 1993 (flammable liquids) and loading rack. The AST's appear to be in containment (Photograph 2) but with an opening in the containment wall for possible access. I could not determine containment for the loading rack. The AST's and loading rack are covered. Based on my Public Roadside Inspection, I conclude that Saveway Petroleum appears to be regulated under 40 CFR 112 because: The facility is a non-transportation-related company storing oil, distributing, consuming, and transporting oil and oil products; the ASTs appear to contain more than 1,320 gallons of above ground oil and due its location could reasonably be expected to discharge oil into or upon navigable waters of the United States (Cold Brook).

I departed the area at 1545.

A. Opening Conference

N/A

B. Facility Tour

N/A

C. Records Review

N/A

D. Closing Conference

N/A