Mr. Degan

Bell Laboratories

600 Mountain Avenue
Murray Hill, New Jersey 07974
Phone (201) 582-3000

September 30, 1977

PLAINTIFF'S EXHIBIT

SWB-83

Dr. Charles Steinmetz
N. Y. Telephone Co.
1095 Ave. of the Americas
New York, N.Y. 10036

Dear Dr. Steinmetz:

Attached is a copy of the ES Laboratories report on the bulk sample from Yankee Stadium you submitted for analysis. The analysis shows the sample contains 10 percent chrysotile (asbestos) fibers. /

Please contact me at (201) 582-7519 if you have any further questions.

Sincerely,

Roy Deitchman

MH-7885-RWD-jm

Roy Deitchman
Industrial Hygienist

Att.
ES Laboratories Report

Copy (with Att.) to
R. L. Beach - AT&T - Basking Ridge
R. W. Stone, M.D. - " "

THIS COPY FOR

W. J. Schreibeis
G. M. Wilkening

CONFIDENTIAL

003556

ES LABORATORIES

CHEMICAL ANALYSES

CUSTOMER: BELL TELEPHONE LABORATORIES, INC. DATE: 9/26/77

REPORT NO.: 1662 Report #84963 P.O. NO.:270193 INVOICE NO.:3631

REPORTED AS: Mineral Phases Present (Crystalline phases)

			Bulk Sample			
Chrysotile (asbestos)			10%			
Calcite			45%			
Gypsum			30%			
Un-named mineral (non-asbestos)			10%			

ANALYST: George A. Brown
GEORGE A. BROWN Jr

8 S. MAPLE AVENUE MARLTON, NEW JERSEY 08053 (609) 983-3616

003557

CONFIDENTIAL