2/9/61

Bryan, Texas

PLAINTIFF'S EXHIBIT JMMC-226

5 years

2" U.S. Pipe & F

installed by Andrews

and Parker in 1952

Recently closed Hydrant

too quickly — resulting

surge broke corroded

2" pipe in 14 places

in approx. 2 Blocks

stretch

Navasota, Texas 2/9/61

Last fall, subject elected to

buy Belgian pipe from Viking (who

offered their choice of Italian

or Belgian).

City bought F.O.B.; let labor

(installing) contract to Andrews-Parker

in attempting to test, plumbicity

of burst pipe, at little

or no pressure. Contractor stopped

(over)

COPY FORM	INITIALS	DATE
	CSP	10-19-99

BOX NUMBER	SEGMENT NO!	REQUESTING PARTY
04-1913		B+B

NOTES

work, tossed lemon back to city. City threatened to sue Viking, who reportedly replaced pipe and paid for all repairs.
Conclusion: Pipe was damaged somewhere between Belgium and Navasota. Should have been completely tested and proven out after reaching U.S.