ENERGY SUPPORT INC.

5200 Manchester Avenue
Saint Louis, Missouri 63110
314/644/1179

Consulting & Managing
Maintaining & Servicing
Electrical Utilities &
Industrial Equipment

January 19, 1983

Monsanto Company
Corporate Research Laboratories
800 North Lindbergh
St. Louis, Missouri 63166

Attn: Mr. Richard J. Edwards

Dear Mr. Edwards:

With regard to the six (6) oil samples taken from your Lackland Road facility, we are pleased to forward the following results in P.P.M. of P.C.B. content.

Sample No.	S/N	Identification	Total P.P.M.
1. 12684	157329	Wagner 1000 K.V.A. Unit A	Less than 1
2. 12792	157330	Wagner 1000 K.V.A. Unit B	7
3. 12790	157331	Wagner 1000 K.V.A. Unit C	6
4. 12776	None	Wagner Instrument Trans. A	2
5. 12475	49703	Wagner Instrument Trans. B	Less than 1
6. 12350	None	Wagner Instrument Trans. C	Less than 1

We thank you for this opportunity to have been of service.

Should any questions arise, or if we can be of further service, please feel free to call at anytime.

Sincerely,
ENERGY SUPPORT, INC.

Joe Murawski

Joe Murawski
Manager, Maintenance Division

JM/sg

cc: Mr. Jim Midgette
Corporate Sq. Bldg. #4

MONS 003013