PLAINTIFF'S EXHIBIT CHV-270

BILL OF MATERIAL

JOB 18-439 NH_3 INJECTION FAC. DATE 12-11-83

DRG. No. _____ SHEET _____ ORDER No. BM-83848

APPRO. JOB No. FRC01-6119-01-300

M.D. COUNTEGAN x 356 MATERIAL REQ'D AT DEST'N BY 12-14-83* FIRM
DATE

ITEM	QUANTITY	UNIT	DESCRIPTION	REMARKS
23	1	EA.	CONTROL VALVE - 1" - 300#	
			- CAMFLEX II 35002 SERIES	
			w/ FULL TRIM Cv =	13.6
			- CRITICAL FLOW FACTOR C_F =	0.88
			- FLOW TO OPEN	
			- 35-35102 - MODEL No.	
			POSITIONER 4000 SERIES	
			MODEL No. 4612	
31	1	EA.	BARTON MODEL 202A FLOW RECORDER (12" CHART)	
			HOUSING MAT'L: FORGE STL. A.I.S.I. C-1018	
			SWP: 1,000 PSI	
			D/P RANGE: 2 1/8" O.D. S.S. BELLOWS	0-15 PSI TO 0-75 PSI
			PIPE MOUNTED	
			* AIR FREIGHT & O/T AUTHORIZED	
			TO MEET DELIVERY DATE (12-14-83)	
			[signature] 12/11/83	
			M.D. Countegan 12-11-83	
32	10 (OR MINIMUM)	EA	FOXBORO OR EQUAL 12" CIRCULAR CHART PAPER	
			No. 898246 w/ RANGE 0-90√	
			END USE: NEW CIV.	
			FOR NH_3 INJECTION @ FCC FLUE GAS	

SHEET 2 OF 2 SHEETS

CHEV B8 5688

MFG. 334 (25M 2-53) PRINTED IN U.S.A.