

- ¹² F. C. Houghten and Margaret Ingels: ASHVE RESEARCH REPORT No. 786—Infiltration through plastered and unplastered brick walls (ASHVE TRANSACTIONS, Vol. 33, 1927, p. 377). G. L. Larson, D. W. Nelson, and C. Braas: ASHVE RESEARCH REPORT No. 826—Air infiltration through various types of brick wall construction (ASHVE TRANSACTIONS, Vol. 35, 1929, p. 183). G. L. Larson, D. W. Nelson, and C. Braas: ASHVE RESEARCH REPORT No. 851—Air infiltration through various types of brick wall construction (ASHVE TRANSACTIONS, Vol. 36, 1930, p. 99). G. L. Larson, D. W. Nelson and C. Braas: ASHVE RESEARCH REPORT No. 868—Air infiltration through various types of wood frame construction (ASHVE TRANSACTIONS, Vol. 36, 1930, p. 397).
- ¹³ A. M. Simpson and K. B. Atkinson: The infiltration problem of multiple entrances (ASHVE JOURNAL SECTION, Heating, Piping and Air Conditioning, June 1936, p. 345). A. M. Simpson: Infiltration characteristics of entrance doors (REFRIGERATING ENGINEERING, June 1936).
- ¹⁴ W. H. Carrier, R. E. Chertse and W. A. Grant: Modern Air Conditioning, Heating and Ventilating (Pitman Publishing Corporation, 2nd Edition, 1950, p. 57). American Architect Time Saver Standards Series, No. 66: Heat transmission and infiltration through doors, windows and glass masonry (American Architect and Architecture, Vol. 149, No. 2651, Nov. 1936, p. 163).
- ¹⁵ L. F. Schutrum, N. Ozisik, C. M. Humphrey, and J. T. Baker: Air Infiltration Through Revolving Doors (ASHRAE TRANSACTIONS, Vol. 67, 1961, p. 488).
- ¹⁶ T. C. Min: Engineering Concept and Design of Controlling Infiltration and Traffic Through Entrances in Tall Commercial

Buildings (International Conference on Heating, Ventilating and Air Conditioning, London, September 27-October 4, 1961).

¹⁷ State Building Construction Code Applicable to One- and Two-Family Dwellings (New York State Building Code Commission).

¹⁸ W. C. Randall and E. W. Conover: Predetermining airtightness of industrial buildings (ASHVE TRANSACTIONS, Vol. 37, 1931, p. 605).

BIBLIOGRAPHY

- J. B. Dick: Experimental Studies in Natural Ventilation of Houses (Department of Scientific and Industrial Research, Building Research Station Note No. 180, Garston, Watford, England).
- J. B. Dick: Measurement of ventilation using tracer gas technique (ASHVE JOURNAL SECTION, Heating, Piping and Air Conditioning, May 1950, p. 131).
- J. B. Dick and D. A. Thomas: Ventilation Research in Occupied Houses (Journal of the Institution of Heating and Ventilating Engineers, October 1951, p. 306).
- C. W. Coblenz and P. R. Achenbach: Design and performance of a portable infiltration meter (ASHAE TRANSACTIONS, Vol. 63, 1957, p. 477).
- F. C. Houghten, J. L. Blackshaw, and Carl Guthrie: ASHVE RESEARCH REPORT No. 994—Wind velocities near a building and their effect on heat loss (ASHVE TRANSACTIONS, Vol. 40, 1934, p. 387).

HEATING LOAD

General Procedure, Design Outdoor Weather Conditions, Indoor Temperatures, Attic Temperatures, Temperatures in Heated Spaces, Ground Temperatures, Basement Temperatures and Heat Loss, Heat Losses from Floor Slabs, Transmission Heat Loss, Infiltration Heat Loss, Selection of Wind Speeds, Auxiliary Heat Sources, Intermittently Heated Buildings, Residence Heat Loss Problems

PRIOR to designing a heating system, an estimate must be made of the maximum probable heat loss of each room or space to be heated, based on maintaining a selected indoor air temperature during periods of design outdoor weather conditions. The heat losses may be divided into two groups: (1) the transmission losses or heat transmitted through the confining walls, floor, ceiling, glass, or other surfaces, and (2) the infiltration losses or heat required to warm outdoor air which leaks in through cracks and crevices, around doors and windows, or through open doors and windows, or heat required to warm outdoor air used for ventilation.

GENERAL PROCEDURE

The general procedure for calculating heat losses of a structure is:

1. Select the design outdoor weather conditions: temperature, wind direction, and wind speed. The data on climatic conditions given in Table 1 will be helpful, but should be used with judgment as suggested in the section Design Outdoor Weather Conditions.
2. Select the indoor air temperature that is to be maintained in each room during the coldest weather. (See Table 2.)
3. Estimate temperatures in adjacent unheated spaces and the attic. (See section, Attic Temperatures.) The attic temperature need not be estimated if the combined roof and ceiling coefficient is used.
4. Select or compute the heat transmission coefficients for outside walls and glass, and for inside walls, floors, or top-floor ceilings, if these are next to unheated space; include roof if next to heated space. (See Chapter 24. If the design wind speed is appreciably different from 15 mph, the appropriate change in the heat transmission coefficients in Tables 5 to 15 of Chapter 24 can be found in Table 20 of that chapter.)
5. Determine net area of outside wall, glass, and roof next to heated space, as well as any cold walls, floors, or ceilings next to unheated space. Such measurements are made from building plans, or from the actual building, using inside dimensions.
6. Compute the heat transmission losses for each kind of wall, glass, floor, ceiling, and roof in the building by multiplying the heat transmission coefficient in each case by the area of the surface in square feet, and the temperature difference between the indoor and outdoor air. (See Items 1, 2, and 3.)
7. Select unit values and compute the heat equivalent of the infiltration of cold air taking place around outside doors and windows. These unit values depend on the kind or width of crack, wind speed, and the temperature difference between the indoor and outdoor air; the result expresses the heat required to warm up the cold air leaking into the building per hour. (See Chapter 25.)
8. When positive ventilation using outdoor air is provided by an air-heating or an air-conditioning unit (see Table 1 of Chapter 7, Table 2 of Chapter 27), the heat required to warm the outdoor air to room temperature must be provided by the unit. If mechanical exhaust from the room is provided, in an amount equal to the outdoor air drawn in by the unit, the natural infiltration losses must also be provided for by the unit. If no mechanical exhaust is used, and the outdoor air supply

The general responsibility for this chapter is assigned to TC 2.1, Load Calculations Data and Procedures; and TC 2.2, Weather Data and Design Conditions.

equals or exceeds the amount of natural infiltration that would occur without ventilation, the natural infiltration may be neglected.

9. The sum of the heat losses due to transmission (Item 6) through the outside walls and glass, as well as through any cold floors, ceilings, or roof, plus the heat equivalent (Item 7) of the cold air entering by infiltration, or required to replace mechanical exhaust, represents the total heat loss equivalent for any building.

10. In buildings that have a reasonably steady internal heat release of appreciable magnitude from sources other than the heating system, a computation of this heat release under design conditions should be made for deduction from the total of the heat losses computed in Items 1-9. This is especially important for heating systems of high initial cost or those for which a demand charge is based on installed capacity.

DESIGN OUTDOOR WEATHER CONDITIONS

The ideal solution to the basic problem which confronts the designer of a heating system is to design a plant that has a capacity at maximum output just equal to the heating load which develops when the most severe weather conditions for the locality occur.

In most cases, economics interferes with the attainment of this ideal. Studies of weather records show that the most severe weather conditions do not repeat themselves every year. If heating systems were designed with adequate capacity for the maximum weather conditions on record, there would be considerable excess capacity during most of the operating life of the system.

Recommended design temperatures, together with the range of wind velocities associated with severe cold, are presented in Table 1. All the data are based on detailed records from official weather stations of the U. S. Weather Bureau, U. S. Air Force, U. S. Navy, and Canadian Department of Transport.¹⁻⁴

With few exceptions, the data were from airport stations, where hourly observations have been made by trained observers for a sufficient period of years to permit reasonably accurate definition of the climatic range for each station.

Three temperature levels are offered for each station. The Median of Extremes is the middle value of the coldest temperature recorded each year for periods up to 25 or 30 years, and is approximately equal numerically to the Average Annual Minimum published in some previous editions. In the Canadian table, the Average Annual Minimum is the value listed. The 99 and 97½ percent values represent the temperatures which equalled or exceeded these proportions of the total hours (2160) in December, January, and February. In a normal winter there would be approximately 22 hr at or below the 99 percent value, and approximately 54 hr at or below the 97½ percent design value.

The wind data shown in Column 6 pertain specifically to velocities which occur coincident with periods of extreme

(Text continued on p. 477)