TABLE 2. INFILTRATION THROUGH WINDOWS

Expressed in Cubic Feet per Foot of Crack per Hour[a]

TYPE OF WINDOW	REMARKS	WIND VELOCITY, MILES PER HOUR					
		5	10	15	20	25	30
Double-Hung Wood Sash Windows (Unlocked)	Around frame in masonry wall—not calked[b]	3	8	14	20	27	35
	Around frame in masonry wall—calked[b]	1	2	3	4	5	6
	Around frame in wood frame construction[b]	2	6	11	17	23	30
	Total for average window, non-weather-stripped, 1/8-in. crack and 3/32-in. clearance.[c] Includes wood frame leakage[d]	7	21	39	59	80	104
	Ditto, weatherstripped[d]	4	13	24	36	49	63
	Total for poorly fitted window, non-weather-stripped, 3/32-in. crack and 3/32-in. clearance.[c] Includes wood frame leakage[d]	27	69	111	154	199	249
	Ditto, weatherstripped[d]	6	19	34	51	71	92
Double-Hung Metal Windows[f]	Non-weatherstripped, locked	20	45	70	96	125	154
	Non-weatherstripped, unlocked	20	47	74	104	137	170
	Weatherstripped, unlocked	6	19	32	46	60	76
Rolled Section Steel Sash Windows[k]	Industrial pivoted, 1/8-in. crack[g]	52	108	176	244	304	372
	Architectural projected, 3/32-in. crack[h]	15	36	62	86	112	139
	Architectural projected, 1/8-in. crack[h]	20	52	88	116	152	182
	Residential casement, 1/16-in. crack[i]	6	18	33	47	60	74
	Residential casement, 3/32-in. crack[i]	14	32	52	76	100	128
	Heavy casement section, projected, 1/16-in. crack[j]	3	10	18	26	36	48
	Heavy casement section, projected, 3/32-in. crack[j]	8	24	38	54	72	92
Hollow Metal, vertically pivoted window[f]		30	88	145	186	221	242

[a] The values given in this table, with the exception of those for double-hung and hollow metal windows are 20 percent less than test values to allow for building up of pressure in rooms, and are based on test data, reported in the papers listed in chapter footnotes.

[b] The values given for frame leakage are per foot of sash perimeter, as determined for double-hung wood windows. Some of the frame leakage in masonry walls originates in the brick wall itself, and cannot be prevented by calking. For the additional reason that calking is not done perfectly and deteriorates with time, it is considered advisable to choose the masonry frame leakage values for calked frames as the average determined by the calked and non-calked tests.

[c] The fit of the average double-hung wood window was determined as 1/8-in. crack and 3/32-in. clearance by measurements on approximately 600 windows under heating season conditions.

[d] The values given are the totals for the window opening per foot of sash perimeter, and include frame leakage and so-called *elsewhere leakage*. The frame leakage values included are for wood frame construction, but apply as well to masonry construction assuming a 50 percent efficiency of frame calking.

[e] A 3/32-in. crack and clearance represent a poorly fitted window, much poorer than average.

[f] Windows tested in place in building, so that no reduction from test values is necessary, as mentioned in footnote a.

[g] Industrial pivoted window generally used in industrial buildings. Ventilators horizontally pivoted at center or slightly above, lower part swinging out.

[h] Architecturally projected made of same sections as industrial pivoted, except that outside framing member is heavier, and it has refinements in weathering and hardware. Used in semi-monumental buildings such as schools. Ventilators swing in or out and are balanced on side arms. 3/32-in. crack is obtainable in the best practice of manufacture and installation, 1/8-in. crack considered to represent average practice.

[i] Of same design and section shapes as so-called *heavy section casement*, but of lighter weight. 1/16-in. crack is obtainable in the best practice of manufacture and installation, 3/32-in. crack considered to represent average practice.

[j] Made of heavy sections. Ventilators swing in or out and stay set at any degree of opening. 1/16-in. crack is obtainable in the best practice of manufacture and installation, 3/32-in. crack considered to represent average practice.

[k] With reasonable care in installation, leakage at contacts where windows are attached to steel framework and at mullions, is negligible. With 1/8-in. crack, representing poor installation, leakage at contact with steel framework is about one third, and at mullions, about one-sixth of that given for industrial pivoted windows in the table.

poorly fitted window. All of the figures for double-hung wood windows are for the *unlocked* condition. Just how a window is closed, or fits when it is closed, has considerable influence on the leakage. The leakage will be high if the sash are short, if the meeting rail members are warped, or if the frame and sash are not fitted squarely to each other. It is possible to have a window with approximately the average crack and clearance that will have a leakage at least double that of the figures shown. Values for the average double-hung wood window in Table 2 are considered to be easily obtainable figures, provided the workmanship on the window is good. Should it be

known that the windows under consideration are poorly fitted, the larger leakage values should be used. Locking a window generally decreases its leakage, but in some cases may push the meeting rail members apart and increase the leakage. On windows with large clearances, locking will usually reduce the leakage.

Wood casement windows may be assumed to have the same unit leakage as for the average double-hung wood window when properly fitted. Locking, a normal operation in the closing of this type of window, maintains the crack at a low value.

For metal pivoted sash, the length of crack is the total perimeter of the movable or ventilating sections. Frame leakage on steel windows may be neglected when they are properly grouted with cement mortar into brick work or concrete. When they are not properly sealed, the linear feet of

TABLE 3. INFILTRATION THROUGH 72-INCH REVOLVING DOOR AND 36-INCH SWINGING DOOR[a,b]

(Cubic Feet per Person per Passage)

USAGE	FREELY-REVOLVING DOOR	DOOR EQUIPPED WITH BRAKE
Infrequent	75	60
Average	60	50
Heavy	40	40
39-Inch Swinging Door	100	

[a] These figures are based on the assumption that there is no wind pressure and that swinging doors are in use in one wall only. Any swinging doors in other walls should be kept closed to insure air conditioning in accordance with these recommended standards.

[b] From Application Engineering Standards for Air Conditioning for Comfort 1947, *Air Conditioning & Refrigerating Machinery Association, Inc.*, Washington, D. C. Used by permission.

sash section in contact with steel work at mullions should be figured at 25 percent of the values given in Table 2 for industrial pivoted windows.

When storm sash are applied to well fitted windows, some reduction in infiltration is secured; the application of the sash provides an air space which reduces the heat transmission and helps prevent the frosting of the windows.[3] By applying storm sash to poorly fitted windows, a reduction in leakage of 50 percent may be obtained, the effect so far as air leakage is concerned, being roughly equivalent to that obtained by the installation of weatherstrips.

Door Leakage

Doors vary greatly in fit because of their large size and tendency to warp. For a well fitted door, the leakage values for a poorly fitted double-hung wood window may be used. If poorly fitted, twice this figure should be used. If weatherstripped, the values may be reduced one-half. A single door which is frequently opened, as might be the case in a store, should have a value applied which is three times that for a well fitted door. This extra allowance is for opening and closing losses, and is kept from being greater by the fact that doors are not used as much in the coldest and windiest weather.

The infiltration rate through swinging and revolving doors is generally a matter of judgment by the engineer making *cooling* load determinations, and in the absence of adequate research data, the values given in Table 3