PLAINTIFF'S EXHIBIT BRK-120

ARGONAUT REALTY DIVISION

GENERAL MOTORS CORPORATION

INTER-ORGANIZATION LETTERS ONLY

SUBJECT	Argonaut Job No. 2018	DATE	March 28, 1966
FROM	J. V. Bonar	ADDRESS	Argonaut - Detroit
TO	Mr. H. L. Winter	ADDRESS	Argonaut - Detroit

Addition to Mfg. Building
Inland Manufacturing Division
Vandalia, Ohio

Meeting was held on March 24, 1966, at the offices of the Industrial Commission of Ohio in Columbus, Ohio. Purpose of meeting was to obtain permission to use gas direct fired fresh air heaters in connection with a mixed-air ventilating and heating system for Jobs No. 2018 and 1873.

The following were in attendance:

Messrs.	J. F. Ridenour	-	Chief, Engineering & Hygiene
	D. Dewitt Huffman	-	Asst. Chief Eng. & Hygiene
	K. Robinson	-	G.M. Industrial Hygiene 313-575-2791
	P. Eshelman	-	" " "
	J. V.Bonar	-	Argonaut

Argonaut's proposed plan for using gas direct fired fresh air heater with modifications to permit either 25% or 100% fresh air during winter operation was presented and accepted. Plans were based on using roof mounted heaters similar to type being supplied for Chevrolet - Willow Run, Job No. 2036.

Although the proposed plan was accepted by the Industrial Commission, formal approval of final plans and specifications will be by the Division of Factory and Building Inspection.

During this meeting Mr. Huffman called Mr. C. Daubenmire, acting chief of the Factory and Building Inspection and discussed the acceptance. Mr. Daubenmire suggested that when plans are submitted for approval a covering letter regarding this meeting be attached.

Based on this acceptance, bulletins will be issued to change gas fresh air heaters from indirect to direct fired on Jobs No. 1873 and 2018.

J. V. Bonar

ss
cc: Messrs. J. Ridenour
H. Avery
L. E. Mandeville
M. L. Williams
P. Darin

28.