

Part B Response

Part B Response to incident reported on: 14/03/2023

Any more accurate information on the matters for notification under Part A	Power spike observed at the site on 17/02/2023 (electrical fault at a substation in Penwortham, Preston) no sample collected 17/02/2023.															
Measures taken, or intended to be taken to prevent a recurrence of the incident	Additional daily check of autosampler by AGCCE outside operator/sustainability team to ensure the autosampler is programmed to collect sample following power failure.															
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	Following missed sample on 17/02/2023 composite samples have been obtained with no abnormal results identified. A summary is provided below of daily pH and suspended solids tests. <table><tr><th>Week commencing</th><th>pH (weekly average)</th><th>Suspended Solids (weekly average, mg/L)</th></tr><tr><td>06/02/2023</td><td>7.33</td><td>31.66</td></tr><tr><td>13/02/2023</td><td>7.41</td><td>31.13</td></tr><tr><td>20/02/2023</td><td>7.47</td><td>28.34</td></tr><tr><td>27/02/2023</td><td>7.21</td><td>48.00</td></tr></table>	Week commencing	pH (weekly average)	Suspended Solids (weekly average, mg/L)	06/02/2023	7.33	31.66	13/02/2023	7.41	31.13	20/02/2023	7.47	28.34	27/02/2023	7.21	48.00
Week commencing	pH (weekly average)	Suspended Solids (weekly average, mg/L)														
06/02/2023	7.33	31.66														
13/02/2023	7.41	31.13														
20/02/2023	7.47	28.34														
27/02/2023	7.21	48.00														
The dates of any unauthorised emissions from the installation in the preceding 24 months	30/06/2022 Breach of suspended solids limit 16/12/2022 Breach of R22 & R125 - Weekly Average at the Low Boiler Stack (CAR: BU5453IY/0451901) 22/12/2022: Breach of R22 - Weekly Average at the Waste Acid Stack (CAR: BU5453IY/0451578) 06/01/2023: Breach of annual CO limit															

Name*	
Post	
Signature	
Date	14/03/2023

*authorised to sign on behalf of AGC Chemicals Europe