

To: Distribution

From: Dalton York


Date: January 19, 1998

Subject: 1998 Annual VCM Survey

The 1998 Annual VCM Survey has been completed. This survey is used by maintenance to locate and repair the listed VCM leaks and to determine fugitive VCM emissions.

Attached is a list of three VCM response values. There were no VCM leaks above the specified 10,000 ppm.

If there are any questions concerning this survey, please contact me at extension 3594.



Dalton York
Co-op Environmental Engineer

cc: PJK, JEN, KGA, BRD, DEK, WSC, NVS, File
8.1.10.2