



120 Yatesville Road
PO Box 112
Shenandoah, PA 17976
Phone: (570) 462-2822
Fax: (570) 462-3224

March 28, 2025

Mr. Lee Zeldin, Administrator
US Environmental Protection Agency
1200 Pennsylvania Avenue, NW
Washington, DC 20460
Mail Code 1101A
Via Email: airaction@epa.gov

Subject: Presidential Exemption: National Emissions Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam Generating Units Review of the Residual Risk and Technology Review (89 FR 38508; May 7, 2024) ("MATS Rule"): SCHUYLKILL ENERGY RES/ ST. NICHOLAS COGEN PROJ

Dear Administrator Zeldin:

Schuylkill Energy Resources, Inc. ("SER") is requesting a Presidential Exemption to the MATS Rule as set forth herein. In accordance with President Trump's offer to consider an exemption request on the pending changes to the MATs rule, SER is providing information for your evaluation in granting an exemption and providing additional time for us to meet these requirements.

Rule related to the request

"National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam Generating Units Review of the Residual Risk and Technology Review" (89 FR 38508; May 7, 2024) (MATS Rule)

40 CFR Part 63 Subpart UUUUU – Effective Date July 6, 2027

Emission standards subject to the request

- 0.01 Lb/MMBtu of filterable particulate matter (PM) per million BTU heat input

Limitations subject to the request

- General requirement to use a PM CEMs or HAP metals CEMS
- Prohibition of using the LEE option for filterable PM or non-mercury HAP metals.