

TABLE 4. AREAS OF FLANGED FITTINGS, SQUARE FEET^a

NOMINAL PIPE SIZE (INCHES)	FLANGED COUPLING		90 DEG ELL		LONG RADIUS ELL		TEE		CROSS	
	Standard	Extra Heavy	Standard	Extra Heavy	Standard	Extra Heavy	Standard	Extra Heavy	Standard	Extra Heavy
1	0.320	0.438	0.795	1.015	0.892	1.083	1.235	1.575	1.622	2.07
1 1/4	0.383	0.510	0.957	1.098	1.084	1.340	1.481	1.925	1.943	2.53
1 1/2	0.477	0.727	1.174	1.332	1.337	1.874	1.815	2.68	2.38	3.54
2	0.672	0.848	1.65	2.01	1.84	2.16	2.54	3.09	3.32	4.06
2 1/2	0.841	1.107	2.09	2.57	2.32	2.76	3.21	4.05	4.19	5.17
3	0.945	1.484	2.38	3.49	2.68	3.74	3.66	5.33	4.77	6.95
3 1/2	1.122	1.644	2.98	3.96	3.28	4.28	4.48	6.04	5.83	7.89
4	1.344	1.914	3.53	4.64	3.96	4.99	5.41	7.07	7.03	9.24
4 1/2	1.474	2.04	3.95	5.02	4.43	5.46	6.07	7.72	7.87	10.07
5	1.622	2.18	4.44	5.47	5.00	6.02	6.81	8.52	8.82	10.97
6	1.82	2.78	5.13	6.99	5.99	7.76	7.84	10.64	10.08	13.75
8	2.41	3.77	6.98	9.76	8.56	11.09	10.55	14.74	13.44	18.97
10	3.43	5.20	10.18	13.58	12.35	15.60	15.41	20.41	19.58	26.26
12	4.41	6.71	13.08	17.73	16.35	18.76	19.67	26.65	24.87	34.11

^aIncluding areas of accompanying flanges bolted to the fitting.

outer surface temperatures of the insulations. This method of stating conductivities makes it possible readily to calculate the heat loss through single or compound sections. It should be emphasized that the conductivities given in Table 5 for the various insulations are the average of values obtained from a number of tests made on each type of material, also that all variables due to differences in thickness, pipe sizes, and air conditions are eliminated. Individual manufacturer's materials will, of course, vary in conductivity to some extent from these values.

The heat losses through six of the types of insulation given in Table 5 for 1, 1 1/2 and 2-in.-thick materials, and for temperatures commonly encountered in engineering practice can be obtained from Tables 6 to 11,

TABLE 5. CONDUCTIVITIES (*k*) OF VARIOUS TYPES OF INSULATING MATERIALS FOR MEDIUM AND HIGH TEMPERATURE PIPES^a

TYPES OF INSULATING MATERIALS	MEAN TEMPERATURE				
	100 F	200 F	300 F	400 F	500 F
85 per cent Magnesia Type.....	0.425	0.465	0.505	0.550	0.590
Corrugated Asbestos Type.....	0.530	0.650	0.770	0.890	
(4 Plies per 1 in. thick)					
Corrugated Asbestos Type.....	0.480	0.555	0.630	0.705	
(8 Plies per 1 in. thick)					
Laminated Asbestos Type.....	0.360	0.415	0.470	0.525	0.585
(30-40 Laminations per 1 in. thick)					
Laminated Asbestos Type.....	0.545	0.605	0.665	0.725	0.785
(20 Laminations per 1 in. thick)					
Rock Wool Type.....	0.350	0.410	0.470	0.530	0.590
High Temperature Type.....	0.515	0.545	0.575	0.605	0.635
(Diatomaceous Earth and Asbestos)					
Brown Asbestos Type.....	0.600	0.640	0.675	0.715	0.750
(Felted Fibre)					

^aR. H. Heilman, *Mechanical Engineering*, Vol. 46 (1924), p. 593.

TABLE 6. COEFFICIENTS OF TRANSMISSION (*U*) FOR PIPES INSULATED WITH 85 PER CENT MAGNESIA TYPE INSULATION

These coefficients are expressed in *Btu per hour per square foot of pipe surface per degree Fahrenheit difference in temperature between pipe and surrounding still air at 70 F*

THICKNESS OF INSULATION (INCHES)	NOMINAL PIPE SIZE (INCHES)	HOT WATER				STEAM		
		120 F	150 F	180 F	210 F	227.1 F (5 Lb)	297.7 F (50 Lb)	337.9 F (100 Lb)
		TEMPERATURE DIFFERENCE						
		50 F	80 F	110 F	140 F	157.1 F	227.7 F	267.9 F
1	1/2	0.744	0.754	0.764	0.774	0.779	0.802	0.814
	3/4	0.672	0.681	0.689	0.697	0.701	0.721	0.731
	1	0.613	0.621	0.629	0.637	0.641	0.659	0.670
	1 1/4	0.562	0.570	0.577	0.585	0.589	0.606	0.617
	1 1/2	0.532	0.539	0.546	0.553	0.557	0.573	0.582
	2	0.500	0.506	0.512	0.519	0.523	0.538	0.547
	2 1/2	0.475	0.481	0.487	0.493	0.497	0.512	0.520
	3	0.455	0.461	0.467	0.474	0.477	0.492	0.500
	3 1/2	0.441	0.447	0.452	0.458	0.462	0.475	0.483
	4	0.429	0.435	0.441	0.446	0.449	0.463	0.471
	4 1/2	0.420	0.425	0.431	0.437	0.440	0.453	0.460
	5	0.411	0.416	0.422	0.427	0.430	0.443	0.450
1 1/2	1/2	0.617	0.625	0.633	0.642	0.646	0.665	0.676
	3/4	0.550	0.558	0.566	0.573	0.577	0.596	0.606
	1	0.496	0.503	0.511	0.518	0.522	0.540	0.549
	1 1/4	0.453	0.459	0.465	0.472	0.475	0.490	0.498
	1 1/2	0.424	0.430	0.436	0.442	0.445	0.459	0.467
	2	0.394	0.400	0.405	0.410	0.413	0.427	0.434
	2 1/2	0.371	0.376	0.382	0.386	0.389	0.401	0.408
	3	0.352	0.357	0.362	0.367	0.370	0.380	0.387
	3 1/2	0.339	0.343	0.347	0.351	0.354	0.364	0.370
	4	0.328	0.333	0.337	0.341	0.343	0.353	0.359
	4 1/2	0.320	0.324	0.328	0.332	0.334	0.343	0.350
	5	0.312	0.316	0.320	0.324	0.326	0.336	0.342
2	1/2	0.543	0.551	0.558	0.565	0.569	0.587	0.597
	3/4	0.484	0.490	0.497	0.503	0.507	0.523	0.532
	1	0.433	0.439	0.445	0.451	0.454	0.467	0.476
	1 1/4	0.393	0.398	0.403	0.409	0.412	0.424	0.432
	1 1/2	0.365	0.370	0.376	0.381	0.384	0.397	0.402
	2	0.338	0.343	0.347	0.351	0.354	0.364	0.370
	2 1/2	0.316	0.320	0.324	0.328	0.331	0.341	0.347
	3	0.297	0.301	0.305	0.309	0.312	0.321	0.326
	3 1/2	0.284	0.288	0.292	0.295	0.297	0.306	0.311
	4	0.275	0.278	0.282	0.285	0.287	0.296	0.301
	4 1/2	0.266	0.270	0.273	0.276	0.278	0.286	0.290
	5	0.258	0.262	0.265	0.268	0.270	0.278	0.283
	6	0.250	0.254	0.257	0.260	0.262	0.270	0.274
	8	0.236	0.239	0.242	0.245	0.247	0.255	0.258
	10	0.224	0.227	0.230	0.233	0.235	0.242	0.246
	12	0.219	0.222	0.225	0.228	0.230	0.237	0.240