PCB loss control 10/25/(12)

Att

PCB information for staff meeting.

① Losses from Dept. 246 this month are about 2.5#/da
Probably due to 217-246 balance difficulties and discontinued air blowing.
2.5#/day now compare with 0.3# established in part.

② Losses at incinerator lower than past at 0.1#/d
This is good.

③ WTP Influent @ 9#/day
Effluent @ 4#/day

WK Strategy meeting held 10/20
Minutes being published.

DSW 296057