

TABLE 2. FACTORS TO BE USED IN DETERMINING VALUES OF OUTSIDE SURFACE COEFFICIENTS (f_o) UNDER MOVING AIR CONDITIONS.

IN EACH CASE, THE MOVING AIR FACTOR IS BASED ON STILL AIR COEFFICIENT f_i FOR SAME MATERIAL. FOR CONDITIONS WHERE WIND VELOCITY IS NOT KNOWN USE THE FACTOR (3) OR TAKE f_o AS 3 f_i FOR SAME MATERIAL.

WIND VELOCITY IN MILES PER HOUR	BRICKWORK	MULTIPLIERS OF f_i WOOD	AVERAGE
5	2.38	2.19	2.28
10	3.20	2.71	2.96
15	3.76	2.95	3.36b
20	4.22	3.02	3.62
Additional Values—Smooth Surface			
10	-----	2.20	-----
20	-----	2.60	-----
Above 20	-----	3.00	-----

^aTaken from Engineering Experiment Station Bulletin No. 102, of the University of Illinois. Additional values from Engineering Experiment Station, Pennsylvania State College, reported by Professor Wood. Tests at Pennsylvania State College indicate character of surface, rough or smooth, more important than material of surface.

^bThis is usually taken as 3 even.

that values of k and C as well as U are dependent on the temperature range, and it is therefore desirable that the investigator determine heat-transmission values under conditions approximating those existing under actual conditions.

In the case of air-space construction, an air-space coefficient for each air space must be inserted in either equation (5) or (6). Thus for a simple wall with one air space,

TABLE 3. CONDUCTANCES OF AIR SPACES^a AT VARIOUS MEAN TEMPERATURES

MEAN TEMP. DEG. FAHR.	CONDUCTANCES OF AIR SPACES FOR VARIOUS WIDTHS IN INCHES						
	0.128	0.250	0.364	0.493	0.713	1.00	1.500
20	2.300	1.370	1.180	1.100	1.040	1.030	1.022
30	2.385	1.425	1.234	1.148	1.080	1.070	1.065
40	2.470	1.480	1.288	1.193	1.125	1.112	1.105
50	2.560	1.535	1.340	1.242	1.168	1.152	1.149
60	2.650	1.590	1.390	1.295	1.210	1.195	1.188
70	2.730	1.648	1.440	1.340	1.250	1.240	1.228
80	2.819	1.702	1.492	1.390	1.295	1.280	1.270
90	2.908	1.757	1.547	1.433	1.340	1.320	1.310
100	2.990	1.813	1.600	1.486	1.380	1.362	1.350
110	3.078	1.870	1.650	1.534	1.425	1.402	1.392
120	3.167	1.928	1.700	1.580	1.467	1.445	1.435
130	3.250	1.980	1.750	1.630	1.510	1.485	1.475
140	3.340	2.035	1.800	1.680	1.550	1.530	1.519
150	3.425	2.090	1.852	1.728	1.592	1.569	1.559

^aThermal Resistance of Air Spaces, by F. B. Rowley and A. B. Algren (A.S.H.V.E. TRANSACTIONS, Vol. 35, 1929).

$$U = \frac{1}{\frac{1}{f_i} + \frac{1}{f_o} + \frac{1}{a} + \frac{x}{k}} \quad (7)$$

and for a simple wall of several air spaces having conductances of a_1, a_2, a_3 , etc., the coefficient is:

$$U = \frac{1}{\frac{1}{f_i} + \frac{1}{f_o} + \frac{x}{k} + \frac{1}{a_1} + \frac{1}{a_2} + \frac{1}{a_3} + \text{etc.}} \quad (8)$$

With certain special forms of materials which have irregular air spaces (such as hollow tile) or are otherwise non-homogeneous, it is necessary to use the conductance (C) for the unit construction, in which case $\frac{x}{k}$ is replaced by $\frac{1}{C}$.

Air Spaces and Surface Coefficients

The following from Bulletin No. 102 of the Engineering Experiment Station of the University of Illinois, is pertinent:

In making calculations for heat transmission coefficients of compound walls, an air space may be treated in either of the following ways: the air space may be regarded as a solid insulating material through which the heat passes according to the so-called conductivity theory or considering the transfer by the three methods, radiation, convection, and conduction, the radiation and convection action may be combined into a single surface coefficient and the true conductivity of the air neglected. For every air space two surface coefficients, accordingly, would be considered. If different surfaces enclosed the air space, different surface coefficients would be used for the two walls.

Because reliable air-space conductance values have not been available until recently, it has been the practice in the past, when calculating the heat transmission through constructions containing air spaces, to assign still-air surface values to the surfaces enclosing the air spaces, rather than to consider the air spaces as solid insulating materials. In the 1928 and 1929 editions of THE GUIDE the heat transmission tables were based on the average value of 1.34 for surfaces in still air taken from Table 1, which is equivalent to an air-space conductance of 0.67 B.t.u. per hour per square foot per degree fahrenheit difference in temperature between the two sides.

According to tests conducted at the University of Minnesota, under the direction of Prof. F. B. Rowley, conductances of air spaces for various widths and mean temperatures average somewhat higher than 0.67 (Table 3). These tests indicate that there is practically no increase in the conductance of an air space beyond about 1 in. in width, and that the average conductance of air spaces of this width or greater at a mean temperature of 40 deg. fahr. is about 1.10 B.t.u. per hour per square foot per degree fahrenheit difference in temperature, although this value is probably sufficiently accurate for all air spaces of $\frac{1}{2}$ in. or more in width.

Surface coefficients increase with the velocity of air passing over the surface. Factors for determining conductances of outside surfaces under moving-air conditions are given in Table 2. It is the practice to increase the still-air surface coefficient by the factor 3 to allow for moving-air conditions, which is approximately equivalent to a wind exposure of 15 miles per hour. Thus, the conductance of the average surface for still