MAY 1 1968

Monsanto

FROM (NAME & LOCATION): St. Louis - General Offices

DATE: May 1, 1968 CC:

SUBJECT: Electrical Classification
Around Flaker

REFERENCE: CEA 1430 - Anniston

TO : R. J. Green

Paul Ward called Tuesday, April 30, and asked me about the classification around the flaker in the warehouse expansion. He had read the specifications for the motor control center to be installed near the flaker and they did not appear to him as being dust explosion proof. When he read it to me, I concurred with his thinking. He is going to follow through his chain of command back to the project. It might be well to appraise the project engineer of this situation so that he will be armed and have the answers ready when it comes up.

George O. Hunt

GOH:nlc

0612761

TOWOLDMON0044871