

A.S.H.V.E. VENTILATION STANDARDS²³

It is the intent of the Committee in presenting this report to confine itself to a statement of those requirements which, based on present day knowledge, will provide adequate ventilation for spaces intended for human occupancy. The following standards shall apply to all spaces occupied by human beings in all buildings for which ventilation regulations are to be established.

SECTION I—AIR TEMPERATURE AND HUMIDITY

The *temperature* and *humidity* of the air in such occupied spaces, and in which the only source of contamination is the occupant, shall be maintained at all times during occupancy at an *Effective Temperature*, as hereinafter stated.

The relative humidity shall be not less than 30 per cent, nor more than 60 per cent in any case. The Effective Temperature shall range between 64 deg and 69 deg when heating or humidification is required, and between 69 deg and 73 deg when cooling or dehumidification is required.

These Effective Temperatures shall be maintained at a level of 36 in. above the floor. (See Appendix, Tables A and B).

SECTION II—AIR QUALITY

The air in such occupied spaces shall at all times be free from toxic, unhealthy or disagreeable gases and fumes and shall be relatively free from odors and dust.

In every space coming within the provisions of these requirements and in which the quality of the air is below the standards prescribed by good medical and engineering practices, due to toxic substances, bacteria, dust, excessive temperature, excessive humidity, objectionable odors, or other similar causes, means for ventilating shall be provided so that the quality of the air shall be raised to these standards.

SECTION III—AIR MOTION

The air in such occupied spaces shall at all times be in constant motion sufficient to maintain a reasonable uniformity of temperature and humidity, but not such as to cause objectionable drafts in any occupied portion of such spaces.

The air motion in such occupied spaces, and in which the only source of contamination is the occupant, shall have a velocity of not more than 50 ft per minute, measured at a height of 36 in. above the floor.

SECTION IV—AIR DISTRIBUTION

The air in all rooms and enclosed spaces shall, under the provisions of these requirements, be distributed with reasonable uniformity, and the variation in the carbon dioxide content of the air shall be taken as a measure of such distribution.

The air in a space ventilated in accordance with these requirements, and in which the only source of contamination is the occupant, shall be distributed and circulated so that the variation in the concentration of carbon dioxide, when measured at a height of 36 in. above the floor, shall not exceed one part in 10,000.

SECTION V—AIR QUANTITY

The quantity of air used to ventilate the given space during occupancy shall always be sufficient to maintain the standards of air temperature, air quality, air motion and air distribution as herein required. Not less than 10 cu ft per minute per occupant of the total air circulated to meet these requirements shall be taken from an outdoor source.

APPENDIX

Definitions

For the purposes of these standards the terms used shall be defined as follows:—

Ventilation: The process of supplying or removing air by natural or mechanical means, to or from any space. Such air may or may not have been conditioned. (See *Air Conditioning*).

Air Conditioning: The simultaneous control of all or at least the first three of those factors affecting both the physical and chemical conditions of the atmosphere within any structure. These factors include temperature, humidity, motion, distribution, dust, bacteria, odors, toxic gases, and ionization, most of which affect in greater or lesser degree human health or comfort.

²³Report of A.S.H.V.E. Committee on Ventilation Standards consisting of W. H. Driscoll, *Chairman*, J. J. Aeberly, F. Paul Anderson, L. A. Harding, D. D. Kimball, J. R. McColl, C. L. Riley, W. A. Rowe, Perry West and A. C. Willard, presented at the Semi-Annual Meeting of the Society, Milwaukee, Wis., June, 1932, and adopted by the Society in August, 1932.

CHAPTER 3—VENTILATION AND AIR CONDITIONING STANDARDS

Dry-Bulb Temperature: The temperature of the air which is indicated by any type of thermometer which is not affected by the water vapor content or relative humidity of the air.

Dust: Solid material in a finely divided state, the particles of which are large and heavy enough to fall with increasing velocity, due to gravity in still air. For instance, particles of fine sand or grit, such as are blown on a windy day, the average diameter of which is approximately 0.01 centimeter, may be called dust.

Effective Temperature: An arbitrary index of the degree of warmth or cold felt by the human body in response to temperature, humidity, and movement of the air. Effective temperature is a composite index which combines the readings of temperature, humidity, and air motion into a single value. The numerical value of the effective temperature scale has been fixed by the temperature of saturated air which induces an identical sensation of warmth.

Humidity: The water vapor (either saturated or superheated steam) occupying any space, which may or may not contain other vapors and gases at the same time.

Relative Humidity: A ratio, although usually expressed in per cent, used to indicate the degree of saturation existing in any given space resulting from the water vapor present in that space. The presence of air or other gases in the same space at the same time has nothing to do with the relative humidity of the space, which depends merely on the temperature and partial pressure of the vapor.

Spaces in Which the Only Source of Contamination is the Occupant: Spaces in which the atmospheric contamination results entirely from the respiratory processes of the occupant, including heat, moisture, and odors given off by the body. No manufacturing or industrial processes or other sources of atmospheric contamination, including heat and moisture, than people are considered under this title.

TABLE A. EFFECTIVE TEMPERATURES RANGING FROM 64 DEG TO 69 DEG FOR VARIOUS DRY-BULB TEMPERATURES AND RELATIVE HUMIDITIES FOR STILL AIR FOR PERSONS NORMALLY CLOTHED AND SLIGHTLY ACTIVE^a

(For use when heating or humidification is required)

DRY-BULB TEMPERATURES (DEG FAHR)	RELATIVE HUMIDITIES (PER CENT)						
	30	35	40	45	50	55	60
	EFFECTIVE TEMPERATURES (DEGREES)						
67			64.0	64.2	64.5	64.8	64.3
68			64.3	65.1	65.4	65.7	65.1
69	64.1	64.4	65.1	65.8	66.2	66.5	66.0
70	64.8	65.1	65.8	66.6	67.0	67.3	66.8
71	65.5	65.8	66.2	66.9	67.3	67.7	67.5
72	66.2	66.5	66.9	67.3	67.7	68.1	68.5
73	67.0	67.3	67.7	68.1	68.5	68.9	
74	67.7	68.0	68.4	68.8			
75	68.4	68.7					
76	69.0						

^aSee Fig. 5.

TABLE B. EFFECTIVE TEMPERATURES RANGING FROM 69 DEG TO 73 DEG FOR VARIOUS DRY-BULB TEMPERATURES AND RELATIVE HUMIDITIES FOR STILL AIR FOR PERSONS NORMALLY CLOTHED AND SLIGHTLY ACTIVE^a

(For use when cooling or dehumidification is required)

DRY-BULB TEMPERATURES (DEG FAHR)	RELATIVE HUMIDITIES (PER CENT)						
	30	35	40	45	50	55	60
	EFFECTIVE TEMPERATURES (DEGREES)						
73					69.3	69.7	69.3
74					70.0	71.5	70.1
75			69.1	69.5	70.8	71.3	71.0
76	69.0	69.4	69.9	70.5	71.6	72.1	71.8
77	69.7	70.2	70.7	71.2	72.4	73.0	72.6
78	70.4	70.9	71.4	71.9			
79	71.1	71.6	72.2	72.6			
80	71.8	72.4	72.9				
81	72.5						

^aSee Fig. 5.

^bThis table applies primarily to cases in which the human body has reached equilibrium with the surrounding air. A higher plane of summer effective temperatures is required in places of public assembly where the period of occupancy is short, than is required for offices and industrial plants where the period of occupancy is of longer duration. When the period of occupancy is two hours or less, the dry-bulb temperature shall be 72 F plus one-third of the difference between the outside dry-bulb temperature and 70 F, and the relative humidity shall not exceed 60 per cent. (See also Table 2.)