

## Electric Motors and Machinery

Motors and the machinery which they drive, if both are located in the room, convert all of the electrical energy supplied into heat. This heat is retained in the room if the product manufactured is not removed until its temperature is the same as the room temperature.

If power is transmitted to the machinery from the outside, then only the heat equivalent of the brake horsepower supplied is used. In some mills this is the chief source of heating, and it is frequently sufficient to overheat the building even in zero weather, thus requiring cooling by ventilation the year round. Table 7 shows the heat output equivalent

TABLE 7. HEAT EQUIVALENTS OF VARIOUS SOURCES\*

|                                                            |            |
|------------------------------------------------------------|------------|
| Machinery (Motor in room) = Motor Hp/efficiency x 2544     | Btu/hr.    |
| Machinery (Motor outside room) = Motor Hp x 2544           | Btu/hr.    |
| Electric Lights = Kilowatts x 3413                         | Btu/hr.    |
| Gas (Producer = 150) (Manufactured = 535) (Natural = 1000) | Btu/cu ft. |

\* Additional values are given in Chapter 13, Table 28.

of various sources of heat in a factory. For information concerning the heat supplied by persons, refer to data given in Chapter 6, and also Table 27, Chapter 13. For appliances see Table 28, Chapter 13.

## INTERMITTENTLY HEATED BUILDINGS

In the case of intermittently heated buildings additional heat is required for raising the temperature of the air, the building materials and the material contents of the building to the specified inside temperature. The rate at which this additional heat must be supplied depends upon the heat capacity of the structure and its material contents, and upon the time in which these are to be heated.<sup>15</sup>

This additional heat may be computed and allowed for as conditions require, but inasmuch as the heating system proportioned for taking care of the heat losses will usually have a capacity about 100 percent greater than that required for average winter weather, and inasmuch as most buildings may either be continuously heated or have more time allowed for heating up during the few minimum temperature days, no allowance usually is made, except in the size of boilers or furnaces. For churches, auditoriums and other intermittently heated buildings, additional capacity should be provided.

## RESIDENCE HEAT LOSS PROBLEMS

The following *Examples 6* and *7* will illustrate the procedure for calculating the heat loss of a residence, uninsulated and insulated, in accordance with the recommendations given in this chapter.

*Example 6:* Calculate the heat loss of the residence shown in Fig. 2 located in the vicinity of Chicago. From Table 1, design outdoor conditions are -10 F and 12 mph wind velocity. Inside temperature from Table 2 is assumed to be 70 F. The attic is unheated. Assume ground temperature to be 50 F (see Fig. 3, Chapter 34) under basement and garage floors and 32 F adjoining basement walls. Estimate infiltration losses by the air change method. No wall, ceiling or roof insulation is to be considered in this problem, but all first and second floor windows, except in the garage,

TABLE 8. HEAT LOSS CALCULATION SHEET FOR UNINSULATED RESIDENCE (FIG. 2)

| A                              | B                                                                                             | C                                                                                  | D                                                           | E                                          | F                                                          | G                     |
|--------------------------------|-----------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------|-------------------------------------------------------------|--------------------------------------------|------------------------------------------------------------|-----------------------|
| ROOM OR SPACE                  | PART OF STRUCTURE OR INFILTRATION AIR CHANGES                                                 | NET AREA OR AIR VOLUME                                                             | COEFFICIENT                                                 | TEMP. DIFF. °                              | HEAT LOSS (Btu per hour)                                   | TOTALS (Btu per hour) |
| Bedroom A and Closet           | Walls<br>Glass<br>Ceiling<br>Infiltration (34)*                                               | 238 sq ft<br>40 sq ft<br>252 sq ft<br>1510 cfb <sup>b</sup>                        | 0.29<br>0.45<br>0.74<br>0.018°                              | 80<br>80<br>39.8 <sup>d</sup><br>80        | 5520<br>1440<br>7410<br>2180                               | 16,550                |
| Bedroom B and Closet           | Walls<br>Glass<br>Ceiling<br>Infiltration (34)*                                               | 156 sq ft<br>40 sq ft<br>170 sq ft<br>1020 cfb <sup>b</sup>                        | 0.29<br>0.45<br>0.74<br>0.018°                              | 80<br>80<br>39.8 <sup>d</sup><br>80        | 3620<br>1440<br>5000<br>1470                               | 11,530                |
| Bedroom C and Closet           | Walls<br>Glass<br>Ceiling<br>Infiltration (34)*                                               | 114 sq ft<br>27 sq ft<br>129 sq ft<br>874 cfb <sup>b</sup>                         | 0.29<br>0.45<br>0.74<br>0.018°                              | 80<br>80<br>39.8 <sup>d</sup><br>80        | 2650<br>970<br>3890<br>1260                                | 8,660                 |
| Bedroom D and Closet           | Walls<br>Glass<br>Ceiling<br>Floor over garage<br>Infiltration (34)*                          | 118 sq ft<br>20 sq ft<br>110 sq ft<br>110 sq ft<br>660 cfb <sup>b</sup>            | 0.29<br>0.45<br>0.74<br>0.26<br>0.018°                      | 80<br>80<br>39.8 <sup>d</sup><br>35°<br>80 | 2740<br>720<br>3240<br>960 <sup>p</sup><br>950             | 8,610                 |
| Bathroom 1                     | Walls<br>Glass<br>Ceiling<br>Infiltration (1)*                                                | 30 sq ft<br>14 sq ft<br>55 sq ft<br>440 cfb <sup>b</sup>                           | 0.29<br>0.45<br>0.74<br>0.018°                              | 80<br>80<br>39.8 <sup>d</sup><br>80        | 690<br>500<br>1620<br>630                                  | 3,440                 |
| Bathroom 2                     | Walls<br>Glass<br>Ceiling<br>Floor over garage<br>Infiltration (1)*                           | 79 sq ft<br>9 sq ft<br>35 sq ft<br>35 sq ft<br>280 cfb <sup>b</sup>                | 0.26<br>0.45<br>0.74<br>0.26<br>0.018°                      | 80<br>80<br>39.8 <sup>d</sup><br>35°<br>80 | 1640<br>320<br>1060<br>320 <sup>p</sup><br>400             | 3,740                 |
| Living Room                    | Walls<br>Walls (adjoining garage)<br>Glass<br>Floor<br>Infiltration (14) <sup>b</sup>         | 267 sq ft<br>94 sq ft<br>50 sq ft<br>294 sq ft<br>3745 cfb <sup>b</sup>            | 0.29<br>0.39 <sup>f</sup><br>0.45<br>0.45<br>0.018°         | 80<br>35°<br>80<br>80<br>80                | 6200<br>1250 <sup>p</sup><br>1800<br>720<br>5400           | 14,680                |
| Dining Room                    | Walls<br>Glass (doors)<br>Glass (windows)<br>Floor<br>Infiltration (14) <sup>i</sup>          | 166 sq ft<br>35 sq ft<br>20 sq ft<br>168 sq ft<br>2140 cfb <sup>b</sup>            | 0.29<br>0.65<br>0.45<br>0.45<br>0.018°                      | 80<br>80<br>80<br>80<br>80                 | 3850<br>2380<br>720<br>3080                                | 10,030                |
| Kitchen and Entrance to Garage | Walls<br>Walls (adjoining garage)<br>Glass<br>Door<br>Floor<br>Infiltration (14) <sup>j</sup> | 96 sq ft<br>51 sq ft<br>18 sq ft<br>17 sq ft<br>125 sq ft<br>1595 cfb <sup>b</sup> | 0.29<br>0.39 <sup>f</sup><br>0.45<br>0.51<br>0.45<br>0.018° | 80<br>35°<br>80<br>35<br>80<br>80          | 2220<br>700 <sup>p</sup><br>650<br>300<br>2300             | 6,170                 |
| Lavette and Vestibule          | Walls<br>Walls (adjoining garage)<br>Glass<br>Door<br>Floor<br>Infiltration (14) <sup>k</sup> | 82 sq ft<br>85 sq ft<br>9 sq ft<br>19 sq ft<br>30 sq ft<br>383 cfb <sup>b</sup>    | 0.29<br>0.39 <sup>f</sup><br>0.45<br>0.51<br>0.45<br>0.018° | 80<br>35°<br>80<br>80<br>80<br>80          | 1900<br>1160 <sup>p</sup><br>320<br>780<br>550             | 4,710                 |
| Entrance Hall                  | Walls<br>Door<br>Ceiling<br>Infiltration (2) <sup>l</sup>                                     | 39 sq ft<br>21 sq ft<br>87 sq ft<br>1110 cfb <sup>b</sup>                          | 0.29<br>0.38<br>0.74<br>0.018°                              | 80<br>80<br>39.8 <sup>d</sup><br>80        | 900<br>640<br>2560<br>1600                                 | 5,700                 |
| Garage                         | Walls<br>Glass<br>Doors<br>Infiltration (14) <sup>m</sup><br>Floor<br>Gain adjoining rooms    | 167 sq ft<br>53 sq ft<br>44 sq ft<br>2360 cfb <sup>b</sup><br>29 ft <sup>n</sup>   | 0.29<br>1.13<br>0.51<br>0.018°<br>0.81                      | 45°<br>45<br>45<br>45<br>45                | 2180<br>2700<br>1010<br>1910<br>1060<br>-4420 <sup>p</sup> | 4,450                 |
| Recreation Room <sup>o</sup>   | Walls<br>Glass<br>Floor<br>Infiltration (1) <sup>p</sup>                                      | 220 sq ft<br>8 sq ft<br>287 sq ft<br>2010 cfb <sup>b</sup>                         | 0.10<br>1.13<br>0.10<br>0.018°                              | 38<br>80<br>20<br>80                       | 840<br>720<br>570<br>2890                                  | 5,020                 |
|                                |                                                                                               |                                                                                    |                                                             |                                            | TOTAL                                                      | 103,310               |