



Middle School

CONTRACTING DIVISION

2715 ALPHA STREET, LANSING, MICHIGAN 48910, PHONE: (517) 372-4930

October 27, 1982

Holt Public Schools
4410 Spahr Avenue
Holt, MI 48842

Attention Ron VanErmen

Gentlemen:



200054

Subject Asbestos Removal

Please find attached results of an analysis performed by an independent professional (Clayton Environmental Group). The results indicate asbestos present in all three areas sampled.

Sample 1 - Old boiler room steam line

Sample 2 - Old boiler room cold water line

Sample 3 - Basement steam line

We would like to suggest if you decide to remove insulation from these systems that it be done properly without risk of exposing anyone to this carcinogenic. I have enclosed guidelines set up by the E.P.A. and MYOSHA. If the proper precautions are taken the risk is minimized to the optimum.

These are certain areas where insulation can be encapsulated and therefore not warrenting removal. Keep in mind encapsulation is only short term and will not alleviate the problem in the long run.

The removal of asbestos is a costly and risky task, and should only be done on a time and material basis.



Mr. Ron VanErmen
Holt Public Schools
October 27, 1982
Page 2

I hope this meets with your approval. If you have any further questions or desire additional information, please do not hesitate to call.

Sincerely,

OWENS/CORNING FIBERGLAS

Dean O. Lemon

Dean O. Lemon
Senior Estimator

/bc

cc: ~~Ron~~ Connor, Holt Public Schools
Dick Buxton
Fred Lalonde

Attachments: 2

Enclosures: 2

200055

