


1. 2/10 2010 2010 2010

Neuquén

016524

62

determine how much water injection is req'd to keep
outlet temperature below 1045C/F @ 310°F & 300°F



1220 02/20/04

0.012500 4.000000 0.000000 280000 16/11/00

$$\text{Avg rate} = \frac{2.81 \text{ cm}^3}{30 \times 2.4} = 38.1 \text{ cm}^3/\text{hr} \quad \text{CP. 12/06}$$

Peak Rate $\frac{281}{0.685} = 457 \text{ } ^{16}\text{O}/\text{HR}$. Lets make it for 500 $^{16}\text{O}/\text{HR}$.

THE TOTAL REST PERIOD OF PRESSORF

<u>PERCENTAGE wt % COMPOSITION</u>			
	<u>CASE I</u>	<u>CASE II</u>	<u>CASE III</u>
CNC	42	50	46
KEROSENE	14	28	22
WATER	44	22	32

N33711

FEDIS ENERGY CORP.

D.H. Latham

1/23

67

HEAT REQUIRED CASE 1CPC: $Q = m c_p \Delta T$

$$m = 1 \text{ lb}$$

$$c_p = 0.2 \text{ BTU/lb}^\circ\text{F}$$

$$\Delta T = 300 - 50 = 250^\circ\text{F}$$

$$Q = (1)(0.2)(250)$$

$$Q = 50 \text{ BTU/lb CPC}$$

$$\underline{\underline{Q_{CPC} = 50 \text{ BTU/lb}}}$$

WATER: $Q = \Delta H = H_2 - H_1$

$$H_1 = 14.0 \text{ @ } 50^\circ\text{F}$$

$$H_1 = 18.07 \text{ BTU/lb}$$

$$H_2 = \text{H}_2\text{O @ } 300^\circ\text{F}$$

$$H_2 = 1192.0$$

$$Q = 1192.0 - 18.07$$

$$Q = 1173.93 \text{ BTU/lb H}_2\text{O}$$

$$\underline{\underline{Q_{H_2O} = 1174 \text{ BTU/lb}}}$$

KEROSENE: SENSIBLE HEAT

$$Q = m c_p \Delta T$$

$$m = 1$$

$$c_p = 0.5$$

$$\Delta T = 300 - 50 = 250^\circ\text{F}$$

$$Q = (1)(0.5)(250)$$

$$Q = 125 \text{ BTU/lb}$$

LATENT HEAT

$$Q = m \lambda$$

$$m = 1$$

$$\lambda = 100 \text{ BTU/lb}$$

$$Q = 100 \text{ BTU/lb KEROSENE}$$

$$\text{TOTAL} = 100 + 125$$

$$= 225 \text{ BTU/lb KEROSENE}$$

$$\underline{\underline{Q_{KERO} = 225 \text{ BTU/lb}}}$$

CASE I - CAMP on p1 - CASE I heat req +

$$\begin{array}{rcl}
 \text{CPL:} & (50 \text{ BTU/lb}) (0.42) & = 21.0 \\
 \text{KEROSENE:} & (215 \text{ BTU/lb}) (0.14) & = 31.5 \\
 \text{WATER:} & (1174 \text{ BTU/lb}) (0.44) & = 517.0 \\
 & \text{total} & \underline{569.5}
 \end{array}$$

CASE I - 570 BTU/lb PRESSURE

CASE II

$$\begin{array}{rcl}
 \text{CPL:} & (50) (0.50) & = 25.0 \\
 \text{KEROSENE:} & (225) (0.28) & = 63.0 \\
 \text{WATER:} & (1174) (0.22) & = 258.0 \\
 & & \underline{346.0}
 \end{array}$$


CASE II - 346 BTU/lb PRESSURE

CASE III

$$\begin{array}{rcl}
 \text{CPL:} & (50) (0.46) & = 23.0 \\
 & (225) (0.22) & = 49.5 \\
 & (1174) (0.32) & = 376.0 \\
 & & \underline{448.5}
 \end{array}$$

CASE III - 449 BTU/lb PRESSURE

CALCULATED DRYING REQUIREMENT
FOR LC-CPL
PRESSCAKE



5

BB PRESSCAKE

39.0 % CPL
14.0 % KERO
47.0 % WATER
100.0

CPL: $(50)(0.39) = 19.5$
KERDSENE: $(225)(0.14) = 31.5$
WATER: $(1174)(0.47) = 552.0$
603.0

AVG PLANT BB PRESSCAKE 603 BTU/lb

LEAF TESTS IN LAB (BB)

41.0 % CPL
7.5 % KERO
51.5 % WATER

CPL: $(50)(0.41) = 21.0$
KERDSENE: $(225)(0.075) = 16.9$
WATER: $(1174)(0.515) = 605.0$
642.9

LEAF TESTS - 643 BTU/lb PRESSCAKE

SUMMARY

MAXIMUM HEAT LOAD (RB) 41% CPC - 643 BTU/lb

MINIMUM HEAT LOAD (LC) 50% CPC - 346 BTU/lb

Let's set outlet temp @ 265°F & determine steam requirements.

MAXIMUM HEAT REQUIREMENT

$$\frac{500 \text{ lb/hr CPC}}{0.41} = 1222 \text{ lb/hr PRESSURE}$$

$$1222 (643) = 785000 \text{ BTU/hr}$$

Neglect heat loss

INLET 650°F 200 PSIG ; $H = 1345 \text{ BTU/lb}$

OUTLET 265°F 0.3 PSIG ; $H = 1176 \text{ BTU/lb}$
AVAILABLE $\Delta H = 169 \text{ BTU/lb STEAM}$

$$\text{MAX. } \frac{785000 \text{ BTU/hr}}{169 \text{ BTU/lb}} = 4650 \text{ lb steam/hr @ 650°F}$$

MINIMUM HEAT REQUIREMENT

$$\frac{500 \text{ lb/hr CPC}}{0.50} = 1000 \text{ lb/hr CPC PRESSURE}$$

$$\text{MIN. } \frac{(1000)(346)}{169} = 2050 \text{ lb/hr steam @ 650°F}$$

Try 800°F Steam

Steam 800°F - 200 PSIG

$$H_1 = 1423 \text{ BTU/lb}$$

263°F - 0.3 PSIG


$$H_2 = 1176 \text{ BTU/lb}$$

$$\Delta H = 247 \text{ BTU/lb}$$

$$\text{MAX } \frac{785000}{247} = 3180 \text{ lb/hr.}$$

$$\text{MIN } \frac{346000}{247} = 1400 \text{ lb/hr}$$

EFFECT OF STEAM TEMPERATURE
ON STEAM QUANTITY



TYPE OF PROD OR SERVS _____ DATE OF ISSUE NO _____

SUBJECT _____ WORK _____

COMPUTED _____ DATE _____

500°F - 200 PSIG $H_1 = 1268$
 $H_v = \frac{1176}{92} \text{ Btu/lb}$

MAX $\frac{785000}{92} = 8525$

MIN $\frac{346000}{92} = 3760$

900°F - 200 PSIG $H_1 = 1479$
 $H_v = \frac{1176}{298} \text{ Btu/lb}$

MAX $\frac{785000}{298} = 2640 \text{ lb/hr}$

MIN $\frac{346000}{298} = 1161 \text{ lb/hr}$



FILE OR PROJ OR STUDY

PROJ OR STUDY NO

SUBJECT

WORKS






COMPUTER

DATE

12

Lets try to optimize steam temperature!

The following effects hold in relation to steam temp.



(Neglect this one. Assume bags can be protected by water injection)

"Guaranteed" EFFICIENCY

Outlet Steam Temp	η , %
650	71.0
825	61.5 *
900	58.0

* As per quote from vendor (Petrochem Development)



TITLE OF PROJECT OR STUDY

PROJECT OR STUDY NO

SUBJECT

WORK

COMPUTED

DATE

1/26

19 67

Assume 0.6 factor holds for both superheater cost and cost of Fluid Energy unit,

STEAM TEMP °F	Thermal Eff. %	STEAM RATE (lb/hr)	FLUID ENERGY MILL COST	SUPERHEATER COST	STEAM COST \$/1000	GAS AS COST \$/100
650	71.0	4650	15000	10500	34200	3660
825	61.5	3100	12000	9000	22800	4230
900	58.0	2640	10000	8000	19400	4500

$$0.85 \times 360 \times 24 = 7350 \text{ hr/yr}$$

$$\text{GAS RATE} = \text{COST} \times \frac{\text{HEAT LOAD}}{H \times 1000} \times \text{TIME} \left\{ \begin{array}{l} \text{say } 1000 \text{ Btu/hr} \\ 0.45 \$ / \text{MM Btu} \end{array} \right\}$$

$$\begin{aligned} \text{GAS COST} &= \frac{785000}{H \times 1000} \times 7350 \times \frac{0.45}{1000} \\ &= \frac{2600}{H} \end{aligned}$$

	650°F
MILL	15000
SUPERHEATER	10500
STM	34200
GAS	3660
TTL	63360

	825°F
MILL	12000
SUPERHEATER	9000
STM	22800
GAS	4230
TTL	48030

	900°F
MILL	10000
SUPERHEATER	8000
STM	19400
GAS	4500
TTL	41900

TITLE OF PROJECT STUDY

PROJECT STUDY NO.

SUBJECT

WORKS


COMPUTED BY

D. J. Eastman

DATE

11/26


1967

RELATIVE
COST
M\$

Conclusions: Steam cost is major factor-

LET'S SET INLET STEAM TEMP AT 850°F (455°C)
ARRANGE WATER ADDITION TO PREVENT TEMP FROM EXCEEDING
325°F. SET TEMPERATURE CONTROLLER TO CONTROL SUPERHEATER
OUTLET TEMP TO SET DRYER OUTLET TEMPERATURE AT 275-300.

INSTRUMENTATION



TITLE OF PROJECT OR STUDY

PROJECT OR STUDY NO.

SUBJECT

WORK

COMPUTER

DVE

DATE

1/26

19

67

Required amount of cooling water:

$$850 - 100 = 750^{\circ}\text{F}$$

Cool 750 to 325

$$H @ 750 = 1406$$

$$H @ 325 = 1203$$

$$\Delta H = 203 \text{ BTU/lb}$$

Amt H₂O req'd

$$H \text{ of steam @ } 325^{\circ}\text{F} = 1203$$

$$H \text{ of water @ } 90^{\circ}\text{F} = 58$$

$$1145 \text{ BTU/lb H}_2\text{O}$$

$$\text{STEAM RATE @ } 850 = 2900 \text{ lb/hr}$$

$$\frac{(2900 \text{ lb/hr}) (203 \text{ BTU/lb})}{(1145 \text{ BTU/lb}) (500 \text{ GPM})} = 1.03 \text{ GPM H}_2\text{O @ } 7-100\%$$

Spray water need 0-1.5 gpm