





GROUPING BY CAPACITIES shows the 60- and 80-mw turbines contribute largest blocks of kw; units under 10 mw lowest kw




PRESSURES IN THE 600s are most frequently applied; temperatures ranging from 900 to 949 F strongly predominant

Survey Spots Utility Design Trends

► **ROCKETING NEEDS** for more generating capacity are strikingly shown by the record number of returns received in Powm's present steam central-station survey. In the tables on pp 92-97 are broad details of 233 units installed since January 1947 and projected up to 1951. These units total close to 8.5 million kw, representing about 55 to 60% of announced expansions. Powm's 1947 Survey, published in the June, 1947 issue, reported on 79 units representing almost 3.5 million kw for the same period as the current survey. Efforts were made to avoid reporting the same installation in both surveys. The two studies together give information

on about 75 to 80% of new units. **New Practices.** The tremendous expansion all systems are experiencing, coupled with inflated prices, leads naturally to emphasis on designs that will hold down overall costs. About two-thirds of the reported units will use steam pressures of 800 psig and above, and temperatures of 900 F and above. Only an insignificant number of boilers do not use either or both economizer and air heater; these are in small municipal plants. The predominant use of one boiler per turbine directly reflects the cost-cutting aim as well as the increased reliability of equipment operation. No

information was collected on the number of pure single-unit installations. Probably most of these units are interconnected with other units at the same station at the steam header or boiler-feed header. The trend to utilization of four points and more continues. Most plants using less than four turbines are operating at pressures of 450 psi and below. About 65% of the reported number of boilers will have full-load release rates less than 25,000 Btu cu ft per hr and 45% will be less than 20,000 Btu. While this factor is largely on the furnace design, it nonetheless shows an allowance for



COAL WILL BE MOST USED FUEL with almost universal application of air heaters; note high use of 1 boiler per unit

in fuel quality to the poorer side. The present group of installations includes eight topping turbines, only a small percentage of the entire group of 233; last year's survey had five topping out of 81 units.

A definite try for increased over-all economy appears in the 12 reheat installations reported, most of them at initial and reheat temperatures of 1000 to 1050 F, reheat being applied for its better heat rate rather than moisture control at turbine exhaust.

Of 167 turbines 20,000 kw and larger, only three are air cooled, the remainder being water cooled. Of a total of 233 turbines five are cross-compound with the turbine turning at 3600 rpm and the generator at 1800 rpm; there are 17 turbines running at 1800 rpm and one at 1600 rpm, rest operate at 3600 rpm. By a vast majority most of the installations will use electrically driven auxiliaries, with perhaps a standby turbine-driven feed pump. Only 16 have turbine-driven pumps exclusively. For speed control on fans and pumps a total

of 80 hydraulic couplings and 25 magnetic couplings were reported.

Radical Departures. Projected installations that are radically different and will be watched with interest by the power field are (1) the mercury-steam station being installed by the Public Service Co of New Hampshire (2) the simple-cycle gas turbine with exhaust heat recovery being installed by the Oklahoma Gas and Electric Co. The first installation will consist of two "standard" 7500-kw mercury turbines and boilers supplying steam to a 25,000-kw steam turbine, making a total unit capacity of 40,000 kw.

The gas turbine reported in Sept 1948 Powm, pp 64-71, is a 3500-kw unit working with existing steam-station heat balance to raise station capacity over 6000 kw and improve total heat rate.

ADDITIONAL DATA appear in Fig. 6-9 at right; note particularly the conservative heat releases in Fig. 9, showing provision for changes in coal qualities

