

ELECTRICAL JOB SUMMARY FOR P-645

Field is to install a size 1 starter and a 30 A. fused disconnect on starter rack 2000 as shown on drawing 20A-709. The size 1 starter will be Circuit 2037 for the asbestos dust collector. The 30 A. fused disconnect will be Circuit 2036 for the air conditioner/heater system for the asbestos fluffing room. All connections, devices and fixtures in the asbestos fluffing room will be water tight for washing down. Fixtures and devices will be located as shown on drawing 31A-72000.

Field will route all conduit for circuits 2036, 2037 and LA 7 and 8. Circuits LA 7 and 8 will be picked up from lighting panel "LA" at the environmental lab - drawing 31A-72000.

Castleberry/Sigmund:dls
11/28/77



FORWARDED	11-28-77
FOR	Constr./Bonnier Elect
WORK ORDER NO.	14167

1 BB 0011340 1